

## **OIL ANALYSIS REPORT**

Sample Rating Trend

.....

ISO

# FRICK TYSCHI RB3 (S/N S0173PFMFTHAA3)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

## DIAGNOSIS

#### A Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2	
Sample Number		Client Info		USP0015030	USP216498	USP204980	
Sample Date		Client Info		17 Jul 2024	02 Nov 2020	17 Dec 2019	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ATTENTION	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>8	0	1	2	
Chromium	ppm	ASTM D5185m	>2	0	0	0	
Nickel	ppm	ASTM D5185m		0	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	<1	<1	
Lead	ppm	ASTM D5185m	>2	0	0	2	
Copper	ppm	ASTM D5185m		0	<1	0	
Tin	ppm		>4	0	0	<1	
Antimony	ppm	ASTM D5185m			0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES	ppm	method	limit/base	current	history1	history2	
			IIIIIVDase			· · · · ·	
Boron	ppm	ASTM D5185m		0	2	0	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		0	<1	1	
Manganese	ppm	ASTM D5185m		0	0	<1	
Magnesium	ppm	ASTM D5185m		<1	0	0	
Calcium	ppm	ASTM D5185m		2	2	1	
Phosphorus	ppm	ASTM D5185m		1	0	0	
Zinc	ppm	ASTM D5185m		0	4	0	
Sulfur	ppm	ASTM D5185m	50	55	58	24	
CONTAMINANTS	5	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	<1	<1	3	
Sodium	ppm	ASTM D5185m		1	<1	0	
Potassium	ppm	ASTM D5185m	>20	0	0	1	
Water	%	ASTM D6304	>0.01	0.003	0.004	0.002	
ppm Water	ppm	ASTM D6304	>100	36	41.4	25.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000	<u> </u>	6174	8899	
Particles >6µm		ASTM D7647	>2500	<u> </u>	<u> </u>	1773	
Particles >14µm		ASTM D7647	>320	90	174	40	
Particles >21µm		ASTM D7647	>80	13	32	9	
Particles >38µm		ASTM D7647	>20	0	1	0	
Particles >71µm		ASTM D7647	>4	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>A</b> 22/19/14	21/19/15	20/18/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN) :15:06) Rev: 1	mg KOH/g	ASTM D974	0.005 0.014 0.013 0.015 Contact/Location: SERVICE MANAGER - TYSCHI				

Report Id: TYSCHI [WUSCAR] 06240414 (Generated: 07/21/2024 13:15:06) Rev: 1


Contact/Location: SERVICE MANAGER - TYSCHI




# **OIL ANALYSIS REPORT**










VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	65.6	66.0	66.0	66.4
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
					1 Caral	

Bottom



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Certificate 12367

Contact/Location: SERVICE MANAGER - TYSCHI