


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 30-9 GEA ER2 (S/N 090150)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

### **DIAGNOSIS**

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2017 Feb2022 Jul2024				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0015018	USP237746	USP164830
Sample Date		Client Info		15 Jul 2024	06 Feb 2022	18 Jul 2017
Machine Age	hrs	Client Info		195	75940	46521
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	MARGINAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	3	4	<1
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>3	0	<1	0
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	<1	<1	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		0	0	<1
Phosphorus	ppm	ASTM D5185m		0	0	<1
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	12	15
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	3	2
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.01	0.001	0.003	<b>△</b> 0.014
ppm Water	ppm	ASTM D6304	>100	10	31.6	<b>▲</b> 140
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>△</b> 65507	2345	9129
Particles >6µm		ASTM D7647	>2500	<b>19633</b>	339	2439
Particles >14µm		ASTM D7647	>640	445	15	135
Particles >21µm		ASTM D7647	>160	29	4	27
Particles >38µm		ASTM D7647	>40	0	0	4
Particles >71µm		ASTM D7647	>10	0	0	2
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<b>23/21/16</b>	18/16/11	20/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. : 06240421

Lab Number Unique Number : 11129255 Test Package : IND 2

: USP0015018

Received : 18 Jul 2024 **Tested** : 19 Jul 2024

Diagnosed : 19 Jul 2024 - Doug Bogart

3704 LOUIS RICH DR NEWBERRY, SC

US 29108 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: