

## **OIL ANALYSIS REPORT**

Sample Rating Trend

### NORMAL

### Machine Id KAESER 3913248 - DAYTON SUPERIOR (S/N 1650)

Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jul2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0947638		
Sample Date		Client Info		03 Jul 2024		
Machine Age	hrs	Client Info		33261		
Oil Age	hrs	Client Info		947		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	17		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Vanganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	0		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		6		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		16328		
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34		



# **OIL ANALYSIS REPORT**






VISUAL		methou	iiiiii/base	current	TIIStOLA	Thistory
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.05	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	TIES .	method	limit/base	current	history1	history
Visc @ 40°C	cSt	ASTM D445	46	42.9		
SAMPLE IMAGES	S	method	limit/base	current	history1	history
Color					no image	no image
Bottom					no image	no image
Non-ferrous Metal	ls		Jul3/24			
Viscosity @ 40°C	*****		Jul3/24	Acid Number		
(J_0_6+) X3 40 35 40 + 52[2] 7			Jul3/24 +	20 20 10 00 47/Elnr		
<ul> <li>WearCheck USA - 50</li> <li>: WC0947638</li> <li>: 06240454</li> <li>: 11129288</li> </ul>	1 Madisor Receiv Testeo Diagno	ved :18 d :19		ELEVAT		Solutions - 2 Hughes Ntain Inn, Us 29

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Т: F: (864)862-7653

dward@elevatedindustrial.com



Certificate L2367

Contact/Location: DARRIN WARD - PALFOU