

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

SULLAIR 201711160053 - HANES BRAND

Component Compressor

PG-32 (5 GAL)

DI				

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0964030		
Sample Date		Client Info		03 Jul 2024		
Machine Age	hrs	Client Info		39223		
Oil Age	hrs	Client Info		4200		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		726		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		5		
Calcium	ppm	ASTM D5185m		5		
Phosphorus	ppm	ASTM D5185m		12		
Zinc	ppm	ASTM D5185m		6		
Sulfur	ppm	ASTM D5185m		400		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		51		
Potassium	ppm	ASTM D5185m	>20	5		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42		





OIL ANALYSIS REPORT







Color no image no image **Bottom** no image no image **GRAPHS**













Certificate 12367

Laboratory Sample No.

Lab Number : 06240459

: WC0964030 Unique Number : 11129293 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 18 Jul 2024 **Tested** : 19 Jul 2024

Diagnosed : 20 Jul 2024 - Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: Dallas Burcham dallas.burcham@fs-compression.com T: (336)605-9622

FS-COMPRESSION CO, LLC

203 AERO COURT

GREENSBORO, NC

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (336)605-9844 Contact/Location: Dallas Burcham - AIRGREWC

US 27409