

# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# **SULLAIR 003-102440 - MT OLIVE PICKLE**

Compressor

PG-32 (--- GAL)

#### Recommendation

Resample at the next service interval to monitor. (check for metal).

### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov2014	Mar2017 0ct2018	May2020 Oct2022 A	pr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0964034	WC0897677	WC0673419	
Sample Date		Client Info		10 Jul 2024	19 Apr 2024	26 Apr 2023	
Machine Age	hrs	Client Info		39000	38859	32215	
Oil Age	hrs	Client Info		3000	2000	2897	
Oil Changed		Client Info		Not Changd	N/A	Not Changd	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION		method	limit/base current		history1	history2	
Water		WC Method	>0.1	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	1	<1	
Chromium	ppm	ASTM D5185m	>10	0	<1	<1	
Nickel	ppm	ASTM D5185m		0	<1	<1	
Titanium	ppm	ASTM D5185m		0	<1	<1	
Silver	ppm	ASTM D5185m		0	0	<1	
Aluminum	ppm	ASTM D5185m	>25	0	2	0	
Lead	ppm	ASTM D5185m	>25	0	0	0	
Copper	ppm	ASTM D5185m	>50	0	<1	1	
Tin	ppm	ASTM D5185m	>15	0	<1	<1	
Vanadium	ppm	ASTM D5185m		0	<1	<1	
Cadmium	ppm	ASTM D5185m		0	<1	<1	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		251	274	361	
Molybdenum	ppm	ASTM D5185m		0	<1	<1	
Manganese	ppm	ASTM D5185m		0	0	<1	
Magnesium	ppm	ASTM D5185m		0	2	5	
Calcium	ppm	ASTM D5185m		0	3	<1	
Phosphorus	ppm	ASTM D5185m		1	11	5	
Zinc	ppm	ASTM D5185m		0	4	0	
Sulfur	ppm	ASTM D5185m		588	509	487	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	<1	2	1	
Sodium	ppm	ASTM D5185m		67	65	58	
Potassium	ppm	ASTM D5185m	>20	2	4	5	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	

Acid Number (AN)

mg KOH/g ASTM D8045


0.272


0.20

0.08



## **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2

Visc @ 40°C	cSt	ASTM D445	42	2.5 44	1.4	41.8

SAMPLE IMAGES


Color


**Bottom** 





















Certificate 12367

Laboratory Sample No. Lab Number : 06240460

: WC0964034

Unique Number : 11129294 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 18 Jul 2024 **Tested** 

: 19 Jul 2024 : 20 Jul 2024 - Don Baldridge Diagnosed

**FS-COMPRESSION CO, LLC** 203 AERO COURT GREENSBORO, NC US 27409

Contact: Dallas Burcham

dallas.burcham@fs-compression.com T: (336)605-9622

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (336)605-9844