


OIL ANALYSIS REPORT

ROTO XTEND **ATLAS COPCO APF243380**

Component Compressor



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06240484		
Sample Date		Client Info		17 Jul 2024		
Machine Age	hrs	Client Info		6914		
Oil Age	hrs	Client Info		4829		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	<1		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	0		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		20		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		23		
Zinc	ppm	ASTM D5185m		22		
Sulfur	ppm	ASTM D5185m		78		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
	1401	4.0T1.4.D00.:-	0.4.4			

Acid Number (AN) mg KOH/g ASTM D8045 0.14

0.51




OIL ANALYSIS REPORT







GRAPHS

Bottom









no image

no image





Laboratory Sample No.

Lab Number : 06240484

: UCH06240484 Unique Number : 11129318

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 18 Jul 2024

Tested : 19 Jul 2024 Diagnosed : 20 Jul 2024 - Don Baldridge

Contact: BRYAN BENJAMIN bryan.benjamin@aircompressors.com

T: (502)253-6361 F: (502)254-2523

AIR TECHNOLOGIES INC (LOU)

1302 N ENGLISH STATION RD

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) LOUISVILLE, KY

US 40223-2280