

# **OIL ANALYSIS REPORT**

Area S-46 [289762] GARDNER DENVER S510512 - MORRISSEY INC

Component Compressor

### DIAGNOSIS

# Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

## Wear


All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001670		
Sample Date		Client Info		10 Jul 2024		
Machine Age	hrs	Client Info		41738		
Oil Age	hrs	Client Info		6000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		361		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42		



# **OIL ANALYSIS REPORT**



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	LIGHT			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jul10/24	Appearance	scalar	*Visual	NORML	NORML			
ت ت	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		46.3			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
Jul10/24 -	Color					no image	no image	
	Bottom					no image	no image	
	Ferrous Alloys	ls		Jul10/24				
	Viscosity @ 40°C			Jul10/24	Acid Number			
	50 Abnormal			2.0 4.0 KOH(d) 5.0 A Mumber (mg KOH(d) 1.0 A did Mumber (mg KOH(d) 0.0 A did Mumber (mg KOH(d) 1.0				
	35 				Jul10/24		Jul10/24	
Laboratory Sample No. Lab Number	: UFD0001670 : <mark>06241746</mark>	Recei Teste	Madison Ave., Cary, NC 27513   Received : 19 Jul 2024   Tested : 22 Jul 2024   Diagnosed : 22 Jul 2024 - Wes Davis				FLUID-AIRE DYNAMICS 36 MOUNTAIN VIEW RD MORGANTOWN, PA US 19543 Contact: Service Managel	
Unique Number Test Package		· ·			ves Davis	Contact: Se		

Report Id: UCFLUMOR [WUSCAR] 06241746 (Generated: 07/22/2024 11:32:19) Rev: 1

Contact/Location: Service Manager - UCFLUMOR