

Identité de la machine


4 CYLINDRE

Composant

Système hydraulique


Fluid

TDH FLUID SAE 75W80 (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Tendence des particules



RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

PROBLEMATIC TEST RESULTS

| Statut de l'échant. | | | SEVERE | --- | --- |
|---------------------|--------------|-----------|------------|-----|-----|
| Particules >4µ | ASTM D7647 | >5000 | ▲ 146027 | --- | --- |
| Particules >6µ | ASTM D7647 | >1300 | ▲ 56745 | --- | --- |
| Particules >14µ | ASTM D7647 | >160 | ▲ 1011 | --- | --- |
| Particules >21µ | ASTM D7647 | >40 | ▲ 86 | --- | --- |
| Propreté de l'huile | ISO 4406 (c) | >19/17/14 | ▲ 24/23/17 | --- | --- |

Customer Id: UNISTE
Sample No.: ST
Lab Number: 02620205
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|----------------------|--------|------|---------|---|
| Change Filter | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |
| Resample | --- | --- | ? | Resample in 30-45 days to monitor this situation. |
| Alert | --- | --- | ? | Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. |
| Information Required | --- | --- | ? | Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. |
| Check Breathers | --- | --- | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Dirt Access | --- | --- | ? | We advise that you check all areas where contaminants can enter the system. |
| Filter Fluid | --- | --- | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |

HISTORICAL DIAGNOSIS



Identité de la machine


4 CYLINDRE

Composant

Système hydraulique

Fluid

TDH FLUID SAE 75W80 (--- GAL)



DIAGNOSTIC

▲ Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

Usure

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

État Du Fluide

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

| INFORMATION SUR L'ÉCHANTILLON | | methode | limite/base | actuel | passé1 | passé2 |
|-------------------------------|-------------|-------------|-------------|--------------------|--------|--------|
| Numéro d'échant. | Client Info | | | ST | --- | --- |
| Date d'échant. | Client Info | | | 05 Mar 2024 | --- | --- |
| Âge d la Machine | hrs | Client Info | | 0 | --- | --- |
| Âge de l'huile | hrs | Client Info | | 0 | --- | --- |
| Huile changée | Client Info | | | N/A | --- | --- |
| Statut de l'échant. | | | | SEVERE | --- | --- |

| MÉTALUX D'USURE | | methode | limite/base | actuel | passé1 | passé2 |
|-----------------|-----|---------------|-------------|--------------|--------|--------|
| Fer | ppm | ASTM D5185(m) | >20 | 19 | --- | --- |
| Chrome | ppm | ASTM D5185(m) | >20 | 1 | --- | --- |
| Nickel | ppm | ASTM D5185(m) | >20 | 0 | --- | --- |
| Titane | ppm | ASTM D5185(m) | | 0 | --- | --- |
| Argent | ppm | ASTM D5185(m) | | <1 | --- | --- |
| Aluminium | ppm | ASTM D5185(m) | >20 | 3 | --- | --- |
| Plomb | ppm | ASTM D5185(m) | >20 | <1 | --- | --- |
| Cuivre | ppm | ASTM D5185(m) | >20 | 8 | --- | --- |
| Étain | ppm | ASTM D5185(m) | >20 | <1 | --- | --- |
| Antimoine | ppm | ASTM D5185(m) | | 0 | --- | --- |
| Vanadium | ppm | ASTM D5185(m) | | 0 | --- | --- |
| Béryllium | ppm | ASTM D5185(m) | | 0 | --- | --- |
| Cadmium | ppm | ASTM D5185(m) | | 0 | --- | --- |


| ADDITIFS | | methode | limite/base | actuel | passé1 | passé2 |
|-----------|-----|---------------|-------------|--------------|--------|--------|
| Bore | ppm | ASTM D5185(m) | 10 | 15 | --- | --- |
| Baryum | ppm | ASTM D5185(m) | 10 | 0 | --- | --- |
| Molybdène | ppm | ASTM D5185(m) | 10 | 4 | --- | --- |
| Manganèse | ppm | ASTM D5185(m) | | 0 | --- | --- |
| Magnésium | ppm | ASTM D5185(m) | 100 | 71 | --- | --- |
| Calcium | ppm | ASTM D5185(m) | 3500 | 2193 | --- | --- |
| Phosphore | ppm | ASTM D5185(m) | 1150 | 956 | --- | --- |
| Zinc | ppm | ASTM D5185(m) | 1150 | 1053 | --- | --- |
| Soufre | ppm | ASTM D5185(m) | 3000 | 2916 | --- | --- |
| Lithium | ppm | ASTM D5185(m) | | <1 | --- | --- |

| CONTAMINANTS | | methode | limite/base | actuel | passé1 | passé2 |
|--------------|-----|---------------|-------------|--------------|--------|--------|
| Silicium | ppm | ASTM D5185(m) | >15 | 8 | --- | --- |
| Sodium | ppm | ASTM D5185(m) | | 3 | --- | --- |
| Potassium | ppm | ASTM D5185(m) | >20 | 1 | --- | --- |
| Eau | % | ASTM D6304* | >0.05 | 0.036 | --- | --- |
| ppm d'eau | ppm | ASTM D6304* | >500 | 365 | --- | --- |


| PROPRETÉ DU FLUIDE | | methode | limite/base | actuel | passé1 | passé2 |
|---------------------|--|--------------|-------------|-------------------|--------|--------|
| Particules >4µ | | ASTM D7647 | >5000 | ▲ 146027 | --- | --- |
| Particules >6µ | | ASTM D7647 | >1300 | ▲ 56745 | --- | --- |
| Particules >14µ | | ASTM D7647 | >160 | ▲ 1011 | --- | --- |
| Particules >21µ | | ASTM D7647 | >40 | ▲ 86 | --- | --- |
| Particules >38µ | | ASTM D7647 | >10 | 2 | --- | --- |
| Particules >71µ | | ASTM D7647 | >3 | 1 | --- | --- |
| Propreté de l'huile | | ISO 4406 (c) | >19/17/14 | ▲ 24/23/17 | --- | --- |

RAPPORT D'ANALYSE D'HUILE


Tendance des particules




Eau (KF)




Indice d'acidité



Eau (KF)



Viscosité 40°C



| FLUID DEGRADATION | | methode | limite/base | actuel | passé1 | passé2 |
|-------------------|----------|------------|-------------|-------------|--------|--------|
| Indice d'acidité | mg KOH/g | ASTM D974* | 2.25 | 2.05 | --- | --- |

| VISUEL | | methode | limite/base | actuel | passé1 | passé2 |
|----------------|--------|---------|-------------|--------------|--------|--------|
| Métal blanc | scalar | Visual* | NONE | NONE | --- | --- |
| Bronze | scalar | Visual* | NONE | NONE | --- | --- |
| Préциpié | scalar | Visual* | NONE | NONE | --- | --- |
| Limon | scalar | Visual* | NONE | NONE | --- | --- |
| Débris | scalar | Visual* | NONE | NONE | --- | --- |
| Saleté | scalar | Visual* | NONE | NONE | --- | --- |
| Apparence | scalar | Visual* | NORML | NORML | --- | --- |
| Odeur | scalar | Visual* | NORML | NORML | --- | --- |
| Eau émulsifiée | scalar | Visual* | >0.05 | NEG | --- | --- |
| Eau libre | scalar | Visual* | | NEG | --- | --- |


| PROPRIÉTÉS DU FLUID | | methode | limite/base | actuel | passé1 | passé2 |
|---------------------|-----|---------------|-------------|-------------|--------|--------|
| Visc 40°C | cSt | ASTM D7279(m) | 48 | 40.7 | --- | --- |

IMAGES DE L'ÉCHANTILLON

| | methode | limite/base | actuel | passé1 | passé2 |
|--------|---------|-------------|--------|----------|----------|
| Coluer | | | | no image | no image |
| Fond | | | | no image | no image |

GRAPHIQUES

Alliages ferreux




Métaux non-ferreux



Viscosité 40°C



Comptage de particules



Indice d'acidité



Laboratoire : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
N° d'échantillon : ST **Reçu** : 06 Mar 2024
N° de laboratoire : 02620205 **Tested** : 07 Mar 2024
Numéro unique : 5737315 **Diagnostiqué** : 07 Mar 2024 - Kevin Marson
Analyse : IND 2 (Additional Tests: KF, TAN Man)

Pour discuter cette rapport, contacter le service à la clientèle au 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

La validez de los resultados y la interpretación se basan en la muestra y la información proporcionada.

UNI-DRAULIK
 2995, RUE KEPLER
 STE-FOY, QC
 CA G1X 3V4

Contact: Dominic Cloutier
 dominic.cloutier@unidraulik.ca

T: (418)658-2995
 F: (418)658-3282