

PROBLEM SUMMARY

Sample Rating Trend

ISO


KAESER 5159485

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TES	T RESULTS				
Sample Status			ABNORMAL	NORMAL	
Particles >6µm	ASTM D7647	>1300	△ 3022	1184	
Particles >14μm	ASTM D7647	>80	144	88	
Particles >21µm	ASTM D7647	>20	<u>^</u> 26	20	
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/19/14	17/14	

Customer Id: PARVAL Sample No.: KCP40556 Lab Number: 05621338 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

15 Jun 2021 Diag: Angela Borella

NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER 5159485

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2021	Aug ² 022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP40556	KCP33170	
Sample Date				15 Aug 2022	15 Jun 2021	
Machine Age	hrs			61239	51025	
Oil Age	hrs			0	4463	
Oil Changed				N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	6	11	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES	ррпп	method	limit/base	current		
					history 1	history 2
Boron	ppm	ASTM D5185m	0	1	15	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	100	0 <1	0	
Magnesium	ppm	ASTM D5185m	100		0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	3	3	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	12477	15788	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	7101111 20100111	>25	<1	<1	
Sodium	ppm	ASTM D5185m	00	2	1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.008	0.005	
ppm Water	ppm	ASTM D6304	>500	81.9	51.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		12526	4470	
Particles >6µm		ASTM D7647	>1300	<u>▲</u> 3022	1184	
Particles >14μm		ASTM D7647	>80	<u> </u>	88	
Particles >21μm		ASTM D7647	>20	<u>^</u> 26	20	
Particles >38μm		ASTM D7647	>4	0	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/14	17/14	
FLUID DEGRADA	NOITA	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.48	0.546	



OIL ANALYSIS REPORT





ODADUO			
GRAPHS			
Ferrous Alloys	Particle Count		
iron	431,320	Ī	
**************************************	122,880	+	
	30,720		
	7,680	· · · · · · · · · · · · · · · · · · ·	
Jun15/2'	Aug 15/22. Aug 15/22. 1.920 480	+	
Non-ferrous Metals	Age 480		
Non-terrous metals	Ted 400		
copper	120-	†	
economico til	30		
	8 Sbrese mal		
5/21			
Jun 15/21	27 27 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2		
Viscosity @ 40°C	α 0 4μ 6μ 14μ Acid Number	21μ 38μ 71μ	
-,	Acid Number		
Severe	0.96 - Absermal		
Abnormal	€0.72		
Base Abnomal	1.20 (A)		
Severe	를 0.24		
<u> </u>	ZZ V V V V V V V V V V V V V V V V V V		
Jun15/2'	Aug15/22		





Certificate L2367

Laboratory Sample No. Lab Number

Unique Number

: 10100845

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCP40556 : 05621338

Received : 18 Aug 2022 Diagnosed

: 22 Aug 2022 Diagnostician : Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Bottom

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PARK MANAGEMENT CORP

1001 FAIRGROUNDS DR VALLEJO, CA USA 94589

Contact: Service Manager

T: F:

no image