


PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
KAESER ASD 40S 3491006 (S/N 1011)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	NORMAL
Particles >6µm	ASTM D7647	>1300	▲ 6064	▲ 1733	876
Particles >14µm	ASTM D7647	>80	▲ 828	▲ 105	65
Particles >21µm	ASTM D7647	>20	▲ 124	▲ 25	17
Particles >38µm	ASTM D7647	>4	▲ 5	2	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/20/17	▲ 18/14	17/13

Customer Id: POMMON
Sample No.: KCP40621
Lab Number: 05622450
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

14 Oct 2021 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



10 May 2021 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Nov 2020 Diag: Angela Borella

ISO




The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER ASD 40S 3491006 (S/N 1011)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)



DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history 1	history 2
Sample Number		KCP40621	KCP21027	KCP33068
Sample Date		11 Aug 2022	14 Oct 2021	10 May 2021
Machine Age	hrs	52764	49926	47597
Oil Age	hrs	3000	4000	6000
Oil Changed		Changed	Changed	Changed
Sample Status		ABNORMAL	ATTENTION	NORMAL

WEAR METALS

method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m >50	0	0	0
Chromium	ppm ASTM D5185m >10	0	0	0
Nickel	ppm ASTM D5185m >3	0	<1	0
Titanium	ppm ASTM D5185m >3	0	0	0
Silver	ppm ASTM D5185m >2	0	<1	<1
Aluminum	ppm ASTM D5185m >10	0	<1	0
Lead	ppm ASTM D5185m >10	0	<1	0
Copper	ppm ASTM D5185m >50	8	17	11
Tin	ppm ASTM D5185m >10	<1	<1	0
Antimony	ppm ASTM D5185m	---	0	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	<1	12	<1
Barium	ppm ASTM D5185m 90	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	0	0	0
Magnesium	ppm ASTM D5185m 90	17	5	6
Calcium	ppm ASTM D5185m 2	0	0	0
Phosphorus	ppm ASTM D5185m	7	3	0
Zinc	ppm ASTM D5185m	12	4	0
Sulfur	ppm ASTM D5185m	17897	16763	15827

CONTAMINANTS

method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m >25	<1	0	0
Sodium	ppm ASTM D5185m	9	2	2
Potassium	ppm ASTM D5185m >20	0	1	<1
Water	% ASTM D6304 >0.05	0.014	0.006	0.005
ppm Water	ppm ASTM D6304 >500	142.6	66.8	53.5



FLUID CLEANLINESS

method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	15960	7562	6045
Particles >6µm	ASTM D7647 >1300	▲ 6064	▲ 1733	876
Particles >14µm	ASTM D7647 >80	▲ 828	▲ 105	65
Particles >21µm	ASTM D7647 >20	▲ 124	▲ 25	17
Particles >38µm	ASTM D7647 >4	▲ 5	2	0
Particles >71µm	ASTM D7647 >3	1	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 21/20/17	▲ 18/14	17/13

FLUID DEGRADATION

method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045 0.4	0.30	0.337	0.321


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.9

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP40621 **Received** : 19 Aug 2022
Lab Number : 05622450 **Diagnosed** : 23 Aug 2022
Unique Number : 10101957 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

POMPS TIRE
 2301 KILGUST RD
 MONONA, WI
 USA 53713
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: