


Machine Id
KAESER SM-11 1369476 (S/N 1022)


Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ASTM D7647	ABNORMAL	ATTENTION	ABNORMAL
Particles >6µm	>1300	▲ 3228	923	▲ 3258	
Particles >14µm	>80	▲ 368	▲ 118	▲ 166	
Particles >21µm	>20	▲ 116	▲ 34	▲ 43	
Particles >38µm	>4	▲ 7	▲ 5	▲ 5	
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/19/16	▲ 17/14	▲ 19/15

Customer Id: LANGAI
Sample No.: KC05623090
Lab Number: 05623090
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

30 Jul 2021 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



16 Jul 2020 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



08 Nov 2018 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





Machine Id
KAESER SM-11 1369476 (S/N 1022)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)



DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KC05623090	KC05322126	KC05037349
Sample Date			12 Aug 2022	30 Jul 2021	16 Jul 2020
Machine Age	hrs		88616	81320	78567
Oil Age	hrs		0	5001	3866
Oil Changed			Changed	Changed	Changed
Sample Status			ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	0	<1	<1
Chromium	ppm ASTM D5185m	>10	0	0	0
Nickel	ppm ASTM D5185m	>3	<1	0	1
Titanium	ppm ASTM D5185m	>3	0	0	0
Silver	ppm ASTM D5185m	>2	0	<1	0
Aluminum	ppm ASTM D5185m	>10	<1	0	0
Lead	ppm ASTM D5185m	>10	0	0	0
Copper	ppm ASTM D5185m	>50	3	2	5
Tin	ppm ASTM D5185m	>10	0	0	0
Antimony	ppm ASTM D5185m		---	0	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m		0	14	0
Barium	ppm ASTM D5185m	90	<1	0	<1
Molybdenum	ppm ASTM D5185m		0	0	0
Manganese	ppm ASTM D5185m		0	<1	0
Magnesium	ppm ASTM D5185m	90	4	16	3
Calcium	ppm ASTM D5185m	2	0	0	0
Phosphorus	ppm ASTM D5185m		0	4	4
Zinc	ppm ASTM D5185m		4	0	0

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	0	0	<1
Sodium	ppm ASTM D5185m		2	5	2
Potassium	ppm ASTM D5185m	>20	0	0	12
Water	% ASTM D6304	>0.05	0.015	0.018	0.023
ppm Water	ppm ASTM D6304	>500	152.3	183.2	232.8


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		12577	3306	14154
Particles >6µm	ASTM D7647	>1300	▲ 3228	923	▲ 3258
Particles >14µm	ASTM D7647	>80	▲ 368	▲ 118	▲ 166
Particles >21µm	ASTM D7647	>20	▲ 116	▲ 34	▲ 43
Particles >38µm	ASTM D7647	>4	▲ 7	▲ 5	▲ 5
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/19/16	▲ 17/14	▲ 19/15

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	0.4	0.33	0.312	0.298


OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.8	44.4

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC05623090 **Received** : 22 Aug 2022
Lab Number : 05623090 **Diagnosed** : 23 Aug 2022
Unique Number : 10102597 **Diagnostician** : Jonathan Hester
Test Package : IND 2

LANIER PARK HOSPITAL
 675 WHITE SULPHUR RD
 GAINESVILLE, GA
 USA 30501
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: