


# **PROBLEM SUMMARY**

Sample Rating Trend




7176159 (S/N 1057)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

# **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ATTENTION	ABNORMAL	NORMAL		
Particles >14μm	ASTM D7647	>80	<b>△</b> 98	<u>^</u> 245	34		
Particles >21µm	ASTM D7647	>20	<b>46</b>	<u> </u>	8		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>18/16/14</b>	<b>2</b> 0/18/15	16/12		

Customer Id: SELCOM Sample No.: KC85579 Lab Number: 05623105 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

### 28 Apr 2022 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 13 Dec 2021 Diag: Angela Borella

NORMAL



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 08 Sep 2021 Diag: Don Baldridge

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



ISO

7176159 (S/N 1057)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

# DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

## **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2020 N	lov2020 Feb2021 May20	121 Sep.2021 Dec2021 Apr2022	Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC85579	KC05543229	KC05427073
Sample Date				11 Aug 2022	28 Apr 2022	13 Dec 2021
Machine Age	hrs			19898	17453	14386
Oil Age	hrs			9502	7057	2145
Oil Changed				Changed	Not Changd	Not Changd
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	10	12	7
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	<1	0
Barium	ppm	ASTM D5185m	90	<1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	2	15	36
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		<1	6	6
Zinc	ppm	ASTM D5185m		29	37	24
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		2	6	18
Potassium	ppm	ASTM D5185m	>20	0	<1	3
Water	%	ASTM D6304	>0.05	0.011	0.010	0.014
ppm Water	ppm	ASTM D6304	>500	113.7	100.3	147.8
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		2028	5475	1644
Particles >6µm		ASTM D7647	>1300	523	<u>▲</u> 1505	387
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>4</u> 245	34
Particles >21µm		ASTM D7647	>20	<b>46</b>	<u>▲</u> 105	8
Particles >38μm		ASTM D7647	>4	4	<u>^</u> 29	2
Particles >71µm		ASTM D7647	>3	0	<u>▲</u> 5	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>18/16/14</b>	<b>△</b> 20/18/15	16/12
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.42	0.398




0.00

# **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.9	43.8	43.9
SAMPLE IMAGES	3	method	limit/base	current	history 1	history 2
Color						







Laboratory Sample No. Lab Number

Unique Number : 10102612

: KC85579 : 05623105

**Bottom** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 22 Aug 2022 : 23 Aug 2022 Diagnosed Diagnostician : Jonathan Hester

112 SELIT DR COMMERCE, GA USA 30309 Contact: Service Manager

Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**SELIT** 

T:

F: