

PROBLEM SUMMARY

Sample Rating Trend

ISO

7765585 (S/N 1843)


Component

Compressor

NOT GIVEN (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TES	ST RESULTS			
Sample Status			ABNORMAL	
Particles >6µm	ASTM D7647	>1300	△ 5398	
Particles >14µm	ASTM D7647	>80	591	
Particles >21µm	ASTM D7647	>20	156	
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/20/16	

Customer Id: HORJAM Sample No.: KC102427 Lab Number: 05623114 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS




OIL ANALYSIS REPORT

7765585 (S/N 1843)

Compressor

NOT GIVEN (--- GAL)



DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Aug2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC102427		
Sample Date				16 Aug 2022		
Machine Age	hrs			4500		
Oil Age	hrs			3129		
Oil Changed				Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	8		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		37		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		15		
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		9		
Potassium	ppm	ASTM D5185m	>20	7		
Water	%	ASTM D6304	>0.05	0.028		
ppm Water	ppm	ASTM D6304	>500	281.8		
FLUID CLEANLIN	NESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		18940		
Particles >6μm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<u>^</u> 591		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/20/16		
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.26		



OIL ANALYSIS REPORT





Ferrous Alloys	Particle Count	
iron 1	491,520	
**************************************	122,880	
	30,720	
	7,680	
Aug 1 6/22	Aug 16/22 17/27 17/27 17/27 18	
⊲ Non-ferrous Metals	480	
copper	120-	
**************************************	30	
	8 20	
	Shreemal	
Aug16/22	Aug16/22	
	Φ 0 4μ 6μ 14μ	21μ 38μ 71
Viscosity @ 40°C	Acid Number	
Abnormal	9,030	
	E 0.18	
Abnormal	(B) 0.30 (B) 0.24 (B) 0.18 (B) 0.12 (B) 0.06 (B) 0.06	
	N 0.06	
727		
Aug16/22	Aug 16/22 Aug 16/22	



Certificate L2367

Laboratory Sample No. Lab Number Unique Number Test Package : IND 2

: KC102427 : 05623114 : 10102621

Bottom

Received Diagnosed

Diagnostician

: 22 Aug 2022 : 23 Aug 2022 : Jonathan Hester

JAMES ISLAND, SC USA

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

no image

no image

T:

F: