

PROBLEM SUMMARY

Sample Rating Trend ISO


KAESER 2694994

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS					
Sample Status			ABNORMAL	ABNORMAL	
Particles >6µm	ASTM D7647	>1300	2615		
Particles >14µm	ASTM D7647	>80	472		
Particles >21µm	ASTM D7647	>20	122		
Particles >38µm	ASTM D7647	>4	<u> </u>		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16		

Customer Id: CONPALCA Sample No.: KCP50623 Lab Number: 05623856 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDE	D ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

08 Jul 2021 Diag: Angela Borella

VIS DEBRIS




We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



KAESER 2694994

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2021	Aug ² 022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50623	KCP33313	
Sample Date				21 Aug 2022	08 Jul 2021	
Machine Age	hrs			32215	99999	
Oil Age	hrs			3000	28516	
Oil Changed				Changed	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	2	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m	710		<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
	ρρ		limit/base	-		history O
ADDITIVES		method		current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	8	
Barium	ppm	ASTM D5185m	90	0	<1	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m	100	0	<1	
Magnesium	ppm	ASTM D5185m	100	0	3	
Calcium	ppm	ASTM D5185m	0	3	<1 3	
Phosphorus Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m ASTM D5185m	23500	18399	17210	
	ppm			10099		
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	2	20	
Sodium	ppm	ASTM D5185m		<1	2	
Potassium	ppm	ASTM D5185m	>20	0	10	
Water	%	ASTM D6304		0.007	0.023	
ppm Water	ppm	ASTM D6304	>500	76.2	238.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		5911		
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2615		
Particles >14μm		ASTM D7647	>80	472		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38μm		ASTM D7647	>4	<u>^</u> 5		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16		
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
	1/011/	4 O T 1 D O 0 4 F	4.0		0.440	



OIL ANALYSIS REPORT





Ferrous Alloys	A Particle Count	
Terrous Alloys	491,520 _T	
iron	122,000	
	122,880	
1	30,720	
	7,680	
Jul8/21-	1 ml)	
n r	S (per 1 ml)	
Non-ferrous Metals	Aug 21/22 480 120 - 120	
copper	D 120	

	30+	
	8 Showsmal	
	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
Jul8/21	2+ 2+ 2+	
Viscosity @ 40°C	$ ext{                                  $	21μ 38μ 71
Т;		
Abnormal	1.20 Hy 0.96   Bhoomal 1.20   Bhoomal 1.20   Bhoomal 1.20   Bhoomal 1.20   Bhoomal 1.20   Bhoomal 1.20   Charles   Char	
	€0.72	
Abiloilla	© 0.48	
Severe	≥ 0.24	
Jul8/21	Aug21/22 + Aug21/22 + Aug21/27 + 10	





Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: KCP50623 : 05623856

**Bottom** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received Diagnosed : 10103363

Diagnostician : Doug Bogart

: 25 Aug 2022

: 22 Aug 2022

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CONFLUENCE ENVIRONMENTAL** 

3126 PORTER DR PALO ALTO, CA USA 94304

no image

Contact: Service Manager

T: F: