

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id


KAESER AS 31 1143421 (S/N 3111480)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS Sample Status ATTENTION ABNORMAL -- Particles >14μm ASTM D7647 >80 ▲ 89 -- -- Oil Cleanliness ISO 4406 (c) >--/17/13 ▲ 19/17/14 -- --

Customer Id: SEQKNO Sample No.: KCP50047 Lab Number: 05623901 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action Status Date Done By Description Change Fluid -- -- ? Oil and filter change at the time of sampling has been noted. Change Filter -- ? Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

21 Feb 2017 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. High concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER AS 31 1143421 (S/N 3111480)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Feb 2017	Aug2022		
SAMPLE INFORM	1ATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50047	KCP62011	
Sample Date				15 Aug 2022	21 Feb 2017	
Machine Age	hrs			58989	36647	
Oil Age	hrs			9096	0	
Oil Changed				Changed	Changed	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	10	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	2	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	13	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	<u> </u>	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	0	53	
Calcium	ppm	ASTM D5185m	0	0	26	
Phosphorus	ppm	ASTM D5185m	0	5	8	
Zinc	ppm	ASTM D5185m	0	0	52	
Sulfur	ppm	ASTM D5185m	23500	17021	8511	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	5	<u>^</u> 26	
Sodium	ppm	ASTM D5185m		<1	17	
Potassium	ppm	ASTM D5185m	>20	0	3	
Water	%	ASTM D6304	>0.05	0.006	▲ 0.133	
ppm Water	ppm	ASTM D6304	>500	64.7	▲ 1330	
FLUID CLEANLIN	ESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		4547		
Particles >6µm		ASTM D7647	>1300	973		
Particles >14μm		ASTM D7647	>80	<u>^</u> 89		
Particles >21μm		ASTM D7647	>20	13		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2

Acid Number (AN)



OIL ANALYSIS REPORT





Farrage Allays	A Dortido Count	
Ferrous Alloys	Particle Count	
iron		
**************************************	122,880	
	30,720	
	7,680	
7/1	Aug 15/22 5 (per 1 m)	
Feb21/1	1,920 + 1,920	
Non-ferrous Metals	480 -	
copper	Aug 15/22 Aug 15/22 100 100 100 100 100 100 100	
onessesses tin	30	
		/
	8 Biorese mal	
	2-	
Feb21/17	Aug15/22	
Viscosity @ 40°C	$^{4\mu}$ $^{6\mu}$ $^{14\mu}$ Acid Number	21μ 38μ 71
Severe	1.20 Blazermal Blazerman Blazerman	
	90.96	
Abnormal Base Abnormal	50.72	
Automa	E 0.70	
Severe 0	A O O O	
Feb21/17	Aug15/22 Feb21/17	



Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: KCP50047 : 05623901 : 10103408

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Aug 2022 Diagnosed : 24 Aug 2022

Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

SEQUATCHIE CONCRETE 2100 SUTHERLAND AVE KNOXVILLE, TN

USA 37923

Contact:

no image

T: F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)