


# PROBLEM SUMMARY

Sample Rating Trend





**WATER**



Machine Id  
**KAESER ASD 30 4831842 (S/N 3156)**  
Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185m	>50	▲ <b>92</b>	10	34
Water	%	ASTM D6304	>0.05	▲ <b>0.788</b>	▲ 0.428	0.005
ppm Water	ppm	ASTM D6304	>500	▲ <b>7880</b>	▲ 4280	57.8
Debris	scalar	*Visual	NONE	▲ <b>MODER</b>	NONE	▲ MODER

Customer Id: ARASTL  
Sample No.: KCP48098  
Lab Number: 05629570  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 10 Aug 2021 Diag: Jonathan Hester

#### WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid.

[view report](#)



### 20 Oct 2019 Diag: Jonathan Hester

#### ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 13 Oct 2014 Diag: Doug Bogart

#### WEAR




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



Machine Id  
**KAESER ASD 30 4831842 (S/N 3156)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### ▲ Wear

The copper level is abnormal. All other component wear rates are normal.

### ▲ Contamination

There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			<b>KCP48098</b>	KCP42825	KCP23731
Sample Date			<b>25 Aug 2022</b>	10 Aug 2021	20 Oct 2019
Machine Age	hrs		<b>20558</b>	17434	14449
Oil Age	hrs		<b>3000</b>	10000	5173
Oil Changed			<b>Changed</b>	Changed	Changed
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<b>1</b>	0	<1
Chromium	ppm ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m	>3	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	>3	<b>0</b>	0	0
Silver	ppm ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m	>10	<b>0</b>	<1	0
Lead	ppm ASTM D5185m	>10	<b>0</b>	0	0
Copper	ppm ASTM D5185m	>50	<b>▲ 92</b>	10	34
Tin	ppm ASTM D5185m	>10	<b>0</b>	0	0
Antimony	ppm ASTM D5185m		<b>---</b>	0	10
Vanadium	ppm ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm ASTM D5185m		<b>0</b>	0	<1

## ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	<b>0</b>	10	0
Barium	ppm ASTM D5185m	90	<b>&lt;1</b>	0	0
Molybdenum	ppm ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm ASTM D5185m	100	<b>0</b>	0	0
Calcium	ppm ASTM D5185m	0	<b>0</b>	0	0
Phosphorus	ppm ASTM D5185m	0	<b>2</b>	<1	2
Zinc	ppm ASTM D5185m	0	<b>1</b>	0	0
Sulfur	ppm ASTM D5185m	23500	<b>16959</b>	12286	5660

## CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	<b>&lt;1</b>	0	<1
Sodium	ppm ASTM D5185m		<b>&lt;1</b>	<1	<1
Potassium	ppm ASTM D5185m	>20	<b>0</b>	0	0
Water	% ASTM D6304	>0.05	<b>▲ 0.788</b>	▲ 0.428	0.005
ppm Water	ppm ASTM D6304	>500	<b>▲ 7880</b>	▲ 4280	57.8


## FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		<b>---</b>	8214	39134
Particles >6µm	ASTM D7647	>1300	<b>---</b>	▲ 4106	▲ 12743
Particles >14µm	ASTM D7647	>80	<b>---</b>	▲ 868	▲ 962
Particles >21µm	ASTM D7647	>20	<b>---</b>	▲ 217	▲ 255
Particles >38µm	ASTM D7647	>4	<b>---</b>	▲ 6	▲ 7
Particles >71µm	ASTM D7647	>3	<b>---</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>---</b>	▲ 19/17	▲ 21/17

## FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	<b>0.39</b>	0.476	0.397


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	40.8	49.9

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCP48098 **Received** : 29 Aug 2022  
**Lab Number** : 05629570 **Diagnosed** : 30 Aug 2022  
**Unique Number** : 10114091 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**ARAMARK UNIFORM SERVICES**  
 10822 MIDWEST INDUSTRIAL DR  
 ST LOUIS, MO  
 USA 63132  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: