


PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
KAESER SFC 55 5742486 (S/N 3159)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ATTENTION
Particles >6µm	ASTM D7647	>1300	▲ 3124	---	879
Particles >14µm	ASTM D7647	>80	▲ 207	---	▲ 94
Particles >21µm	ASTM D7647	>20	▲ 43	---	▲ 28
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/19/15	---	▲ 17/14

Customer Id: HENCLE
Sample No.: KCP49347
Lab Number: 05634987
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Aug 2021 Diag: Don Baldrige

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a high concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

view report



28 Jan 2021 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



18 Jun 2018 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report



Machine Id
KAESER SFC 55 5742486 (S/N 3159)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)



DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KCP49347	KCP42772	KCP20927
Sample Date			18 Aug 2022	09 Aug 2021	28 Jan 2021
Machine Age	hrs		38558	29739	25169
Oil Age	hrs		3927	4571	4329
Oil Changed			Not Changed	Not Changed	Changed
Sample Status			ABNORMAL	ABNORMAL	ATTENTION

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	2	<1	<1
Chromium	ppm ASTM D5185m	>10	0	0	0
Nickel	ppm ASTM D5185m	>3	0	0	0
Titanium	ppm ASTM D5185m	>3	0	0	0
Silver	ppm ASTM D5185m	>2	0	0	<1
Aluminum	ppm ASTM D5185m	>10	<1	<1	<1
Lead	ppm ASTM D5185m	>10	0	0	<1
Copper	ppm ASTM D5185m	>50	5	6	2
Tin	ppm ASTM D5185m	>10	0	<1	0
Antimony	ppm ASTM D5185m		---	0	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	0	17	11
Barium	ppm ASTM D5185m	90	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0	0
Manganese	ppm ASTM D5185m		0	<1	<1
Magnesium	ppm ASTM D5185m	100	12	22	28
Calcium	ppm ASTM D5185m	0	0	<1	0
Phosphorus	ppm ASTM D5185m	0	<1	6	1
Zinc	ppm ASTM D5185m	0	116	38	20
Sulfur	ppm ASTM D5185m	23500	17509	17246	16457

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	0	<1	0
Sodium	ppm ASTM D5185m		6	10	11
Potassium	ppm ASTM D5185m	>20	2	4	2
Water	% ASTM D6304	>0.05	0.016	▲ 0.989	0.024
ppm Water	ppm ASTM D6304	>500	161.5	▲ 9890	240.8


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		12492	---	2850
Particles >6µm	ASTM D7647	>1300	▲ 3124	---	879
Particles >14µm	ASTM D7647	>80	▲ 207	---	▲ 94
Particles >21µm	ASTM D7647	>20	▲ 43	---	▲ 28
Particles >38µm	ASTM D7647	>4	1	---	1
Particles >71µm	ASTM D7647	>3	0	---	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/19/15	---	▲ 17/14

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	0.44	0.377	0.489


OIL ANALYSIS REPORT





PARAMETER	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		▲ 1.0	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	46.2	46.6

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP49347 **Received** : 06 Sep 2022
Lab Number : 05634987 **Diagnosed** : 08 Sep 2022
Unique Number : 10124517 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

HENISE TIRE
 558 E PENN AVE
 CLEONA, PA
 USA 17042
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)