


PROBLEM SUMMARY


[72978649] 4698032 (S/N 1286)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST	RESULTS				
Sample Status			ATTENTION	ABNORMAL	
Particles >6µm	ASTM D7647	>1300	1409	<u>^</u> 2759	
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/12	A 19/15	

Customer Id: ICHFRE Sample No.: KCP33319 Lab Number: 05635025 Test Package: IND 2 To manage this report scan the QR code To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED) ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

14 Sep 2021 Diag: Doug Bogart





Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.






OIL ANALYSIS REPORT

[72978649] 4698032 (S/N 1286)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Sep2021	Aug ² 022		
SAMPLE INFOR	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP33319	KCP41887	
Sample Date				29 Aug 2022	14 Sep 2021	
Machine Age	hrs			45362	39496	
Oil Age	hrs			3000	0	
Oil Changed				Changed	Changed	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	2	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	4	10	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	33	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	46	0	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	1	1	
Zinc	ppm	ASTM D5185m	0	23	0	
Sulfur	ppm	ASTM D5185m	23500	18725	17535	
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	3	
Sodium	ppm	ASTM D5185m		4	<1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.020	0.006	
ppm Water	ppm	ASTM D6304	>500	202.3	63.2	
FLUID CLEANLI	NESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		8965	8031	
Particles >6μm		ASTM D7647	>1300	<u> </u>	<u>▲</u> 2759	
Particles >14μm		ASTM D7647	>80	29	<u>^</u> 299	
Particles >21µm		ASTM D7647	>20	6	▲ 80	
Particles >38µm		ASTM D7647	>4	0	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/12	▲ 19/15	
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2

0.448



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	VLITE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	46.8	54.2	
SAMPLE IMAGES	3	method	limit/base	current	history 1	history 2
Color					İ	no image

GRAPHS		
Ferrous Alloys	Particle Count	
iron		
sessesses chromium	122,880	
	30,720	
	7,680	
Sep14/21	Aug 29/22 Number of particles (par 1 m) 120 120	
	Au Au	
Non-ferrous Metals	180 480	
copper	120-	
eau tin	30	
	8 Bibresemal	
, 27/2/	2	
Sep14/21	Aug29/22	
Viscosity @ 40°C	4μ 6μ 14μ	21μ 38μ 71
	Acid Number	
Severe Abanasa	(a) 1.20 (b) 0.72 (c) 0.72 (d) 0.72 (d) 0.72 (e) 0.72 (e) 0.72	
Abnormal	€0.72	
Base - D Abnormal	g 0.48	
Severe	를 0.24	
-		
Sep14/21	Aug29/22 Sep14/21	





Laboratory Sample No. Lab Number Unique Number : 10124555

: KCP33319 : 05635025

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 06 Sep 2022 Diagnosed Diagnostician : Don Baldridge

: 08 Sep 2022

Test Package: IND 2 (Additional Tests: KF, PrtCount)

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ICHOR SYSTEMS - CAL-WELD

4308 SOLAR WAY FREMONT, CA USA 94538

Contact: Service Manager

T:

F:

no image