

PROBLEM SUMMARY


7228444 (S/N 1014)

Component

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)





No relevant graphs to display

RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status				ABNORMAL	ABNORMAL	
Barium	ppm	ASTM D5185m	90	<u> </u>	0	
Magnesium	ppm	ASTM D5185m	100	14	10	

Customer Id: LOFDEN Sample No.: KCP50321 Lab Number: 05635072 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

01 Jul 2021 Diag: Jonathan Hester

VIS DEBRIS




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



7228444 (S/N 1014)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


▲ Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2021	Sep.2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50321	KCP32490	
Sample Date				01 Sep 2022	01 Jul 2021	
Machine Age	hrs			7175	4012	
Oil Age	hrs			4000	3000	
Oil Changed	1110			Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
						Thistory 2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	1	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	7	10	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	12	
Barium	ppm	ASTM D5185m	90	<u> </u>	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	<u> </u>	10	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	<1	1	
Zinc	ppm	ASTM D5185m	0	53	33	
Sulfur	ppm	ASTM D5185m	23500	17442	15392	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		9	6	
Potassium	ppm	ASTM D5185m	>20	2	3	
Water	%	ASTM D6304	>0.05	0.022	0.012	
ppm Water	ppm	ASTM D6304	>500	222.9	127.4	
FLUID CLEANLIN	ESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		5300		
Particles >6µm		ASTM D7647	>1300	1050		
Particles >14μm		ASTM D7647	>80	48		
Particles >21µm		ASTM D7647	>20	8		
Particles >38µm		ASTM D7647	>4	0		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/17/13		
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	▲ MODER	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	47.8	44.4	

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
Color					no image
Bottom					no image
GRAPHS					

GRAPHS		
Ferrous Alloys	Particle Count	
iron]	491,520	
**************************************	122,880	
	30,720	
	7.000	
212	7,680	
Jul1/21	Sep 1/22	
Non-ferrous Metals	Sep 1720 - 1.9	
copper	120	
••••••••••••tin	30+	
	8 Shreemal	
-Jul1/21-	2-27 2-2 2-2 2-2 2-2 2-2 2-2 2-2 2-2 2-2	
과	0	
Viscosity @ 40°C	4μ 6μ 14μ Acid Number	21μ 38μ
Severe	⊋ 1.20 Absormal	
Abnormal	Q 0.96 + 9	
Base	0,1.20 Hommal 1,20 1,	
Abnormal Severe	0.24	
<u> </u>	0.00 PG	
Jul1/2.	Sep1/22 -	





Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10124602

: KCP50321 : 05635072

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 06 Sep 2022 : 08 Sep 2022 Diagnostician : Don Baldridge

Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

LOFLIN FABRICATION LLC

1379 CRANFORD RD DENTON, NC USA 27239

Contact: Service Manager

T:

F: