


PROBLEM SUMMARY

Sample Rating Trend



WATER



Machine Id
8079074 (S/N 1144)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water



RECOMMENDATION

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	---
Water	%	ASTM D6304	>0.05	▲ 0.071	▲ 0.424	---
ppm Water	ppm	ASTM D6304	>500	▲ 719.1	▲ 4240	---
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER	---

Customer Id: HEAGRE
Sample No.: KC103457
Lab Number: 05635074
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

25 Mar 2022 Diag: Jonathan Hester

WATER




We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a moderate concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
8079074 (S/N 1144)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a trace of moisture present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION method limit/base current history 1 history 2

Sample Number			KC103457	KC97471	---
Sample Date			31 Aug 2022	25 Mar 2022	---
Machine Age	hrs		621	375	---
Oil Age	hrs		621	375	---
Oil Changed			Not Changed	Not Changed	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS method limit/base current history 1 history 2

Iron	ppm	ASTM D5185m	>50	1	0	---
Chromium	ppm	ASTM D5185m	>10	0	0	---
Nickel	ppm	ASTM D5185m	>3	0	0	---
Titanium	ppm	ASTM D5185m	>3	0	0	---
Silver	ppm	ASTM D5185m	>2	0	0	---
Aluminum	ppm	ASTM D5185m	>10	<1	<1	---
Lead	ppm	ASTM D5185m	>10	0	<1	---
Copper	ppm	ASTM D5185m	>50	3	2	---
Tin	ppm	ASTM D5185m	>10	0	0	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		0	0	---

ADDITIVES method limit/base current history 1 history 2

Boron	ppm	ASTM D5185m	0	0	0	---
Barium	ppm	ASTM D5185m	90	0	<1	---
Molybdenum	ppm	ASTM D5185m	0	0	0	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m	100	33	51	---
Calcium	ppm	ASTM D5185m	0	0	<1	---
Phosphorus	ppm	ASTM D5185m	0	3	1	---
Zinc	ppm	ASTM D5185m	0	5	5	---

CONTAMINANTS method limit/base current history 1 history 2

Silicon	ppm	ASTM D5185m	>25	0	<1	---
Sodium	ppm	ASTM D5185m		11	5	---
Potassium	ppm	ASTM D5185m	>20	0	2	---
Water	%	ASTM D6304	>0.05	▲ 0.071	▲ 0.424	---
ppm Water	ppm	ASTM D6304	>500	▲ 719.1	▲ 4240	---


FLUID DEGRADATION method limit/base current history 1 history 2

Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.27	0.29	---
------------------	----------	------------	-----	-------------	------	-----

VISUAL method limit/base current history 1 history 2

White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%	---
Free Water	scalar	*Visual		NEG	0.2%	---

OIL ANALYSIS REPORT



FLUID PROPERTIES


method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt ASTM D445	45 43.6	43.4	---

SAMPLE IMAGES


method	limit/base	current	history 1	history 2
Color				no image
Bottom				no image

GRAPHS

Ferrous Alloys




Non-ferrous Metals



Viscosity @ 40°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC103457 **Received** : 06 Sep 2022
Lab Number : 05635074 **Diagnosed** : 08 Sep 2022
Unique Number : 10124604 **Diagnostician** : Don Baldrige
Test Package : IND 2

HEATSINK
 801 INDUSTRIAL PARK DR
 GREENVILLE, MI
 USA 48838
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: