

PROBLEM SUMMARY

Sample Rating Trend

DEGRADATION

DEGINATION

Machine Id


KAESER ESD 250 2587682 (S/N 1047)


Component


Compressor


KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY









RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC 1	EST RE	SULTS				
Sample Status				ABNORMAL	ABNORMAL	
Phosphorus	ppm	ASTM D5185m	500	<u>▲</u> 41	<u></u> 54	
Zinc	ppm	ASTM D5185m		<u></u> <1	<u> </u>	
Sulfur	ppm	ASTM D5185m		△ 360	<u>^</u> 220	
Particles >6µm		ASTM D7647	>1300	^ 7684	986	
Particles >14μm		ASTM D7647	>80	<u>^</u> 215	▲ 83	
Oil Cleanliness		ISO 4406 (c)	>/17/13	23/20/15	▲ 17/14	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	△ 3.32	▲ 3.832	
Visc @ 40°C	cSt	ASTM D445	46	A 86.7	<u> </u>	

Customer Id: DARLANKC Sample No.: KCP50020 Lab Number: 05635086 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

13 May 2020 Diag: Doug Bogart

DEGRADATION



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is above the recommended limit. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirm oil type.





OIL ANALYSIS REPORT


Sample Rating Trend

DEGRADATION

KAESER ESD 250 2587682 (S/N 1047)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The oil viscosity is higher than normal. The AN level is above the recommended limit. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirm oil type.

			May2020	Aug 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50020	KCP26726	
Sample Date				16 Aug 2022	13 May 2020	
Machine Age	hrs			42909	30363	
Oil Age	hrs			12603	0	
Oil Changed				Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	3	0	
_ead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	<1	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<1	<1	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		<1	<1	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m	500	<u>41</u>	<u></u> 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4 ≤ 4	
Zinc	ppm	ASTM D5185m		<u></u> <1	<u> </u>	
Sulfur	ppm	ASTM D5185m		▲ 360	▲ 220	
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	3	
Sodium	ppm	ASTM D5185m		3	3	
Potassium	ppm	ASTM D5185m	>20	0	<1	
Nater	%	ASTM D6304	>0.05	0.016	0.013	
opm Water	ppm	ASTM D6304	>500	166.5	136.4	
FLUID CLEANLIN	NESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		75735	3945	
Particles >6µm		ASTM D7647	>1300	^ 7684	986	
Particles >14µm		ASTM D7647	>80	<u> </u>	▲ 83	
Particles >21µm		ASTM D7647	>20	18	<u>^</u> 24	
Particles >38µm		ASTM D7647	>4	1	2	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	23/20/15	▲ 17/14	
FLUID DEGRADA	NOITA	method	limit/base	current	history 1	history 2

Contact/Location: ? ? - DARLANKC



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCP50020 : 05635086

: 10124616

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 06 Sep 2022 : 08 Sep 2022 Diagnosed Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DART CONTAINER 110 PITNEY RD LANCASTER, PA

USA 17602

Contact:

T:

F: