

# **PROBLEM SUMMARY**


Sample Rating Trend




# KAESER BSD 50 6341469 (S/N 1870)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)



## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST F	DBLEMATIC TEST RESULTS						
Sample Status							
Particles >6µm	ASTM D7647	>1300	<b>1740</b>	427	<b>△</b> 3313		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>21/18/13</b>	16/12	A 19/15		

Customer Id: MORMORTENN Sample No.: KCP50283 Lab Number: 05635090 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

#### 31 Oct 2021 Diag: Jonathan Hester

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 06 Apr 2021 Diag: Jonathan Hester

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 24 Sep 2020 Diag: Angela Borella

NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# KAESER BSD 50 6341469 (S/N 1870)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

## **DIAGNOSIS** Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Jun2019	Mar2020 Sep2020	Apr2021 0et2021	Sep2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50283	KCP36118	KCP32634
Sample Date				02 Sep 2022	31 Oct 2021	06 Apr 2021
Machine Age	hrs			18966	13657	10602
Oil Age	hrs			5309	5347	2392
Oil Changed				Changed	Changed	Not Changd
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	15	23	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррііі		11 11 11			
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	35
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	11	27	73
Calcium	ppm	ASTM D5185m	2	0	0	3
Phosphorus	ppm	ASTM D5185m		2	4	2
Zinc	ppm	ASTM D5185m		19	30	15
Sulfur	ppm	ASTM D5185m		16063	16897	18151
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		6	15	24
Potassium	ppm	ASTM D5185m	>20	<1	7	0
Water	%	ASTM D6304	>0.05	0.014	0.017	0.022
ppm Water	ppm	ASTM D6304	>500	145.7	175.9	224.6
FLUID CLEANLIN	NESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		18891	1661	15604
Particles >6µm		ASTM D7647	>1300	<u> </u>	427	<b>△</b> 3313
Particles >14µm		ASTM D7647	>80	55	36	<b>△</b> 263
Particles >21µm		ASTM D7647	>20	7	8	<b>▲</b> 73
Particles >38µm		ASTM D7647	>4	1	0	3
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	16/12	<u> </u>
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.379	0.352
0000 10.07.01)			•	0		MODMODIENN



# **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.2	44.6	44.5
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom						







Laboratory Sample No. Lab Number Unique Number : 10124620

: KCP50283 : 05635090

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 06 Sep 2022 : 08 Sep 2022 Diagnostician : Don Baldridge **MORRISTOWN MANUFACTURING - IATRIC** 328 HAMBLEN AVE MORRISTOWN, TN

USA 37813

Contact: Service Manager

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: