

# **PROBLEM SUMMARY**


Sample Rating Trend

ISO

# Machine Id KAESER SK26 1387246 (S/N 1023)


Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	<b>^</b> 21929		<b>4</b> 0948		
Particles >14µm	ASTM D7647	>80	<b>2000</b>		<b>4050</b>		
Particles >21µm	ASTM D7647	>20	<b>283</b>		<u></u> 1046		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>23/22/18</b>		<b>2</b> 3/19		

**Customer Id: LUTALL** Sample No.: KC104868 Lab Number: 05636500 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

#### HISTORICAL DIAGNOSIS

#### 05 Aug 2020 Diag: Jonathan Hester

#### VIS DEBRIS



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 08 Aug 2019 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



#### 07 Aug 2018 Diag: Jonathan Hester

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**



# KAESER SK26 1387246 (S/N 1023)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS** Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


		Jun 2017	Aug2018	Aug2019 Aug2020	Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC104868	KC75652	KC73822
Sample Date				17 Aug 2022	05 Aug 2020	08 Aug 2019
Machine Age	hrs			65713	60963	58168
Oil Age	hrs			2613	2795	110
Oil Changed				Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	1	0
Copper	ppm	ASTM D5185m	>50	<1	2	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	13	<1
Barium	ppm	ASTM D5185m	90	53	7	20
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	79	0	81
Calcium	ppm	ASTM D5185m	2	2	2	2
Phosphorus	ppm	ASTM D5185m		<1	2	3
Zinc	ppm	ASTM D5185m		0	3	6
CONTAMINANTS	1	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	4	0
Sodium	ppm	ASTM D5185m		13	14	14
Potassium	ppm	ASTM D5185m	>20	0	3	2
Water	%	ASTM D6304	>0.05	0.034	0.024	0.027
ppm Water	ppm	ASTM D6304	>500	347.5	243.9	276.4
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		58840		104837
Particles >6µm		ASTM D7647	>1300	<u>^</u> 21929		<b>4</b> 0948
Particles >14µm		ASTM D7647	>80	<b>2000</b>		<b>4050</b>
Particles >21μm		ASTM D7647	>20	<u>283</u>		<u> </u>
Particles >38μm		ASTM D7647	>4	9		<b>4</b> 9
Particles >71μm		ASTM D7647	>3	0		1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>23/22/18</b>		△ 23/19
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.38	0.374	0.376



# **OIL ANALYSIS REPORT**



MOLIAL		ام مالم مما	lineit/le e e e		lai atam 14	la i ata m . O
VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	VLITE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.7	44.3	43.5
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom				C		







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC104868 : 05636500

: 10126030

Received

: 08 Sep 2022 Diagnosed : 09 Sep 2022 Diagnostician : Doug Bogart

**LUTRON** 6560 STONEGATE DR ALLENTOWN, PA USA 18106

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: