

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


Machine Id

# KAESER SM 15 6862538 (S/N 1009)


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)



### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ATTENTION	NORMAL	NORMAL		
Particles >6μm	ASTM D7647	>1300	<b>1467</b>	128	304		
Particles >14μm	ASTM D7647	>80	<b>128</b>	13	37		
Particles >21µm	ASTM D7647	>20	<b>^</b> 25	6	14		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/14</b>	14/11	15/12		

Customer Id: ONEREA Sample No.: KC104970 Lab Number: 05636510 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

### 29 Jul 2021 Diag: Don Baldridge

### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 18 Aug 2020 Diag: Don Baldridge

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report

### 05 Sep 2019 Diag: Jonathan Hester

### ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# KAESER SM 15 6862538 (S/N 1009)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

**DIAGNOSIS** 

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Sep 201	9 Aug2020	Jul2021 A	ug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC104970	KC92245	KC87103
Sample Date				18 Aug 2022	29 Jul 2021	18 Aug 2020
Machine Age	hrs			30202	20964	12693
Oil Age	hrs			9238	6000	4512
Oil Changed				Changed	Changed	Changed
Sample Status				ATTENTION	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	11	13	20
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	11	1
Barium	ppm	ASTM D5185m	90	0	26	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	24	28
Calcium	ppm	ASTM D5185m	2	0	0	3
Phosphorus	ppm	ASTM D5185m		0	4	<1
Zinc	ppm	ASTM D5185m		1	23	10
CONTAMINANTS	;	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	2	7
Sodium	ppm	ASTM D5185m		1	18	14
Potassium	ppm	ASTM D5185m	>20	0	<1	2
Water	%	ASTM D6304	>0.05	0.005	0.017	0.024
ppm Water	ppm	ASTM D6304	>500	58.7	174.1	245.0
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		5342	471	991
Particles >6µm		ASTM D7647	>1300	<u> </u>	128	304
Particles >14µm		ASTM D7647	>80	<b>128</b>	13	37
Particles >21µm		ASTM D7647	>20	<u>^</u> 25	6	14
Particles >38μm		ASTM D7647	>4	2	0	1
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/14</b>	14/11	15/12
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.26	0.267	0.217



## **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.0	44.1	44.3
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						







Certificate L2367

Laboratory Sample No. Lab Number Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC104970 : 05636510 Unique Number : 10126040

**Bottom** 

Received Diagnosed

: 08 Sep 2022 : 09 Sep 2022 Diagnostician : Don Baldridge **ONEIDA RESEARCH SERVICES** 4201 POTTSVILLE PIKE, B4A

READING, PA USA 19605

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: