

PROBLEM SUMMARY

Sample Rating Trend




Machine Id KAESER AS 30 6307126 (S/N 1098)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	4500		▲ 17995		
Particles >14µm	ASTM D7647	>80	445		2409		
Particles >21µm	ASTM D7647	>20	<u></u> ▲ 61		▲ 482		
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/19/16		<u>^</u> 21/18		

Customer Id: REVSPR Sample No.: KC102149 Lab Number: 05636533 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

25 Jun 2021 Diag: Doug Bogart

VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



15 Jun 2020 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



17 May 2019 Diag: Angela Borella

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



KAESER AS 30 6307126 (S/N 1098)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		May201	9 Jun2020	Jun 2021 A	ug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC102149	KC92769	KC78578
Sample Date				26 Aug 2022	25 Jun 2021	15 Jun 2020
Machine Age	hrs			8096	5510	3667
Oil Age	hrs			2586	1843	1927
Oil Changed				Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	1	1	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m	90	12	27	12
Molybdenum	ppm	ASTM D5185m		0	0	2
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	77	78	80
Calcium	ppm	ASTM D5185m	2	2	<1	2
Phosphorus	ppm	ASTM D5185m		<1	9	0
Zinc	ppm	ASTM D5185m		2	0	4
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		23	21	23
Potassium	ppm	ASTM D5185m	>20	<1	3	2
Water	%	ASTM D6304	>0.05	0.025	0.032	0.040
ppm Water	ppm	ASTM D6304	>500	257.7	320.1	402.5
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		11227		32908
Particles >6µm		ASTM D7647	>1300	4500		▲ 17995
Particles >14μm		ASTM D7647	>80	445		2409
Particles >21µm		ASTM D7647	>20	<u></u> 61		▲ 482
Particles >38µm		ASTM D7647	>4	1		<u> </u>
Particles >71µm		ASTM D7647	>3	0		1 4
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/16		<u>△</u> 21/18
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.335	0.296



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.7	44.1	44.3
SAMPLE IMAGES	3	method	limit/base	current	history 1	history 2
Color						
Bottom						







Certificate L2367

Laboratory Sample No. Lab Number

Unique Number : 10126063 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC102149 : 05636533

Received : 08 Sep 2022 Diagnosed : 09 Sep 2022 Diagnostician : Don Baldridge

REVIVAL SASH 78 DIAMOND RD SPRINGFIELD, NJ USA 07081 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: