

PROBLEM SUMMARY

Sample Rating Trend




Machine Id **KAESER SM 11 0119432**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	13493		▲ 18348		
Particles >14µm	ASTM D7647	>80	908		△ 2736		
Particles >21µm	ASTM D7647	>20	107		<u>▲</u> 853		
Oil Cleanliness	ISO 4406 (c)	>/17/13	23/21/17		<u>^</u> 21/19		

Customer Id: LUTALL Sample No.: KC104872 Lab Number: 05636538 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

23 Sep 2021 Diag: Don Baldridge

VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



06 Aug 2020 Diag: Don Baldridge

CONTAMINANT



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Appearance is hazy. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Aug 2018 Diag: Jonathan Hester

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER SM 11 0119432

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun2017	Aug2018	Aug2020 Sep2021	Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC104872	KC99887	KC85396
Sample Date				17 Aug 2022	23 Sep 2021	06 Aug 2020
Machine Age	hrs			72872	68998	66925
Oil Age	hrs			1874	2073	1908
Oil Changed				Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	2	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	1
Titanium	ppm	ASTM D5185m	>3	0	<1	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	3	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	1	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m	90	74	72	41
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	81	78	94
Calcium	ppm	ASTM D5185m	2	3	4	2
Phosphorus	ppm	ASTM D5185m		1	10	4
Zinc	ppm	ASTM D5185m		1	0	7
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	4	10
Sodium	ppm	ASTM D5185m		13	10	13
Potassium	ppm	ASTM D5185m	>20	0	2	0
Water	%	ASTM D6304	>0.05	0.030	0.028	0.037
ppm Water	ppm	ASTM D6304	>500	300.9	286.4	374.2
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		51150		50865
Particles >6µm		ASTM D7647	>1300	<u> </u>		<u>▲</u> 18348
Particles >14µm		ASTM D7647	>80	908		▲ 2736
Particles >21µm		ASTM D7647	>20	<u> </u>		<u>▲</u> 853
Particles >38µm		ASTM D7647	>4	3		4 5
Particles >71μm		ASTM D7647	>3	0		3
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 23/21/17		<u>△</u> 21/19
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
Acid Number (AN)	ma KOU/a	ACTM DODAE	0.4	0.30	ი 359	0.392

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.359

0.39


0.392



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
VISUAL		memou	IIIIII/Dase	Current	Thistory I	Thistory 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.6	44.6	43.7
SAMPLE IMAGES	3	method	limit/base	current	history 1	history 2
Color						
Bottom						







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC104872 : 05636538

: 10126068

Received Diagnosed

: 08 Sep 2022 : 09 Sep 2022 Diagnostician : Don Baldridge

LUTRON 6560 STONEGATE DR ALLENTOWN, PA

USA 18106

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: