

PROBLEM SUMMARY

Sample Rating Trend



Machine Id


KAESER SFC 37T 6152777 (S/N 1082)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ATTEN	NTION ABNORMAL	ABNORMAL			
Particles >14μm	ASTM D7647 >	>80 🔺 117	△ 291	<u></u> ▲ 166			
Particles >21µm	ASTM D7647 >	>20 42	△ 52	4 0			
Oil Cleanliness	ISO 4406 (c) >	>/17/13 🔺 19/1	7/14 △ 20/19/15	▲ 18/15			

Customer Id: BRIPIN Sample No.: KC102405 Lab Number: 05636573 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

21 May 2022 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



04 Feb 2022 Diag: Angela Borella

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



05 Nov 2021 Diag: Doug Bogart

VIS DEBRIS




No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER SFC 37T 6152777 (S/N 1082)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2020 F	eb2021 May2021 Aug20	21 Nov2021 Feb2022 May2022	. Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC102405	KC95987	KC98829
Sample Date				19 Aug 2022	21 May 2022	04 Feb 2022
Machine Age	hrs			28680	26525	23987
Oil Age	hrs			2175	4713	6183
Oil Changed				Not Changd	Changed	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	2	0
Copper	ppm	ASTM D5185m	>50	2	3	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	55	32	40
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		1	10	6
Zinc	ppm	ASTM D5185m		15	10	6
CONTAMINANTS	;	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		18	14	18
Potassium	ppm	ASTM D5185m	>20	2	0	2
Water	%	ASTM D6304	>0.05	0.030	0.015	0.013
ppm Water	ppm	ASTM D6304	>500	307.2	156.7	138.5
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		3614	7795	4342
Particles >6µm		ASTM D7647	>1300	957	<u>^</u> 2865	<u>▲</u> 1526
Particles >14µm		ASTM D7647	>80	<u> </u>	291	166
Particles >21µm		ASTM D7647	>20	42	<u>▲</u> 52	4 0
Particles >38μm		ASTM D7647	>4	3	3	4
Particles >71μm		ASTM D7647	>3	0	0	0
		ISO 4406 (c)	>/17/13	A 40/47/44	2 0/19/15	△ 18/15
Oil Cleanliness		130 4406 (C)	>/17/10	<u> </u>	_ 20/13/13	10/13
Oil Cleanliness FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2




0.00

OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	VLITE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	VLITE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	ΓIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.9	42.9	44.0
SAMPLE IMAGE	S	method	limit/base	current	history 1	history 2
Color						
Bottom						







Laboratory Sample No. Lab Number

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC102405 : 05636573 Unique Number : 10126103

Received Diagnosed

: 08 Sep 2022 : 12 Sep 2022 Diagnostician : Don Baldridge

BRIAVE - OPTUM RX 19 CHAPIN RD PINE BROOK, NJ USA 07058 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: