

PROBLEM SUMMARY

Sample Rating Trend

Iso


KAESER 3393273

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6μm	ASTM D7647	>1300	△ 3808						
Particles >14μm	ASTM D7647	>80	<u> </u>						
Particles >21µm	ASTM D7647	>20	△ 35						
Particles >38µm	ASTM D7647	>4	<u>^</u> 6						
Particles >71µm	ASTM D7647	>3	△ 3						
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/19/15						

Customer Id: UNIHAT Sample No.: KC102203 Lab Number: 05636575 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

15 Jun 2021 Diag: Don Baldridge

VIS DEBRIS




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



KAESER 3393273

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Jun2021	Aug2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KC102203	KC68758	
Sample Date				22 Aug 2022	15 Jun 2021	
Machine Age	hrs			98409	98022	
Oil Age	hrs			387	10665	
Oil Changed				Not Changd	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	3	2	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	5	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	0	<1	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		<1	5	
Zinc	ppm	ASTM D5185m		<1	0	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		<1	<1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.007	0.011	
ppm Water	ppm	ASTM D6304	>500	76.6	112.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		11995		
Particles >6µm		ASTM D7647	>1300	4 3808		
Particles >14µm		ASTM D7647	>80	<u>^</u> 210		
Particles >21µm		ASTM D7647	>20	4 35		
Particles >38µm		ASTM D7647	>4	<u>^</u> 6		
Particles >71μm		ASTM D7647	>3	<u>^</u> 3		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.41	0.466	



OIL ANALYSIS REPORT









Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KC102203 : 05636575 : 10126105 Test Package : IND 2

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 08 Sep 2022 : 12 Sep 2022 : Don Baldridge Diagnostician

UNIVERSITY OF SOUTHERN MS POLYMER SCIENCE RESEARCH 118 COLLEGE DR HATTIESBURG, MS

USA 39406

no image

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: