

## **PROBLEM SUMMARY**

# 7396465 (S/N KAESER BALTIMORE)

Compressor



KAESER SIGMA (OEM) FG-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	NORMAL		
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	2		

Customer Id: UNIMOUNJ Sample No.: KCP50011 Lab Number: 05637136 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

#### HISTORICAL DIAGNOSIS



23 Dec 2021 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

Sample Number

hrs

hrs

ppm

ppm

ppm

ppm

ppm

ppm

ppm

ASTM D5185m >10

>10

>50

ASTM D5185m

ASTM D5185m

Sample Date

Machine Age

Oil Changed

Sample Status

WEAR METALS

Oil Age

Iron

Nickel

Silver

Lead

Copper

Titanium

Aluminum

Chromium

Machine Ic 7396465 (S/N KAESER BALTIMORE) Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### A Wear

The aluminum level is abnormal. All other component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	<1	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m	500	384	63	
Zinc	ppm	ASTM D5185m		220	65	
Sulfur	ppm	ASTM D5185m		3699	8470	

15

0

6

2

0

16

CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.004	0.001	
ppm Water	ppm	ASTM D6304	>500	40.3	12.2	

FLUID CLEANLINESS	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		699	1026	
Particles >6µm	ASTM D7647	>1300	199	251	
Particles >14µm	ASTM D7647	>80	24	15	
Particles >21µm	ASTM D7647	>20	7	5	
Particles >38µm	ASTM D7647	>4	0	0	
Particles >71µm	ASTM D7647	>3	0	0	
Oil Cleanliness	ISO 4406 (c)	>/17/13	17/15/12	15/11	

limit/base

Acid Number (AN)

**FLUID DEGRADATION** 

mg KOH/g ASTM D8045 1.5

method

0.89 0.37 Contact/Location: Service Manager - UNIMOUNJ

history 1

current

history 2



## **OIL ANALYSIS REPORT**



	VISUAL		method	limit/base	current	history 1	history 2
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
2/22	Appearance	scalar	*Visual	NORML	NORML	NORML	
Aug	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FI UID PROPER	TIES	method	limit/base	current	history 1	history 2
	Visc @ 40°C	cSt	ASTM D445	46	46.2	44.9	
		001		10	1012	la la la sura d	history O
		5	method	limit/base	current	nistory i	nistory 2
Aud 12/22	Color				J		no image
	Bottom				$\bigcirc$		no image
	GRAPHS						
	Ferrous Alloys			401 520	Particle Count		20
	a iron			431,520	Ţ		120
22	6 + management of the second s			122,880	D-		-24
ud 12/			-	30.720			22
<	2						
	0			7,680	<sup>0</sup>		-20
	c23/2			1,920 La			-18
	De			Aug		<b>`</b>	
	Non-ferrous Meta	als		-11 480			16
	copper			ja 120			+14
	15 - management lead			unu			
	퉡 10-			30	1		-12
	5-				Bibresemal		-10
	c23/2			12/2			
	ă			(	ο 4μ 6μ	14µ 21µ	38µ 71µ
	Viscosity @ 40°C				Acid Number	F	P
	Abnormal			(B <sup>2.00</sup> 관			
	င့္ 50 -			및 1.50 말	) - O		
	(0) Hase			j	) <b>-</b>		
	<sup>33</sup> 45			2 0.50			
	23/21			12/22	23/21		
	Dec.			Aug1	Dec		
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report,	: WearCheck USA - : KCP50011 : 05637136 er : 10126666 e : IND 2 ( Additional T ; contact Customer Serv	501 Madia Received Diagnose Diagnost Tests: KF, vice at 1-8	son Ave., Ca d : 08 % ed : 09 % ician : Dou PrtCount ) 200-237-1368	rry, NC 27513 Sep 2022 Sep 2022 ug Bogart 9.	3 UNIVEF 10	RSAL SYNERG 3 CENTRAL AV MOUN Contact: Se	ETICS - THE /E, SUITE 30 T LAUREL, N USA 0805 Prvice Manage
Sample No. Lab Number Unique Number Test Package o discuss this sample report, - Denotes test methods that tatements of conformity to spe	: KCP50011 : 05637136 ar : 10126666 e : IND 2 ( Additional T contact Customer Serv are outside of the ISO t ecifications are based on the Service of the Ser	Received Diagnost Diagnost Tests: KF, vice at 1-8 17025 sco the simple	d :08 s ed :09 s ician :Dou PrtCount ) pe of accrea acceptance o	Sep 2022 Sep 2022 ug Bogart 9. litation. decision rule (	10 JCGM 106:2012)	03 CENTRAL AV MOUN Contact: Se	/E, SUIT T LAURE USA ervice Ma

Contact/Location: Service Manager - UNIMOUNJ