

PROBLEM SUMMARY

Sample Rating Trend

WEAR


KAESER SK 19 0187601


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|-----|--------------|---------|-----------------|---------------|---------------|--|--|
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL | | |
| Copper | ppm | ASTM D5185m | >50 | <u>^</u> 62 | 25 | △ 76 | | |
| Particles >6µm | | ASTM D7647 | >1300 | 13425 | <u>^</u> 2116 | <u></u> 4185 | | |
| Particles >14µm | | ASTM D7647 | >80 | <u> </u> | △ 360 | △ 341 | | |
| Particles >21µm | | ASTM D7647 | >20 | 476 | <u> </u> | <u>^</u> 79 | | |
| Particles >38μm | | ASTM D7647 | >4 | 48 | △ 18 | <u>^</u> 6 | | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | 23/21/17 | ▲ 18/16 | 1 9/16 | | |

Customer Id: KOCGAI Sample No.: KC05637683 Lab Number: 05637683 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Oct 2019 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



13 May 2019 Diag: Don Baldridge

WEAR



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.



14 Aug 2018 Diag: Angela Borella

ISO




The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR

KAESER SK 19 0187601

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | Jul2016 , | Jul2016 Apr2017 May20 | 18 Aug2018 May2019 Oct2019 | Aug2022 | |
|------------------|----------|--------------|-----------------------|----------------------------|----------------|----------------|
| SAMPLE INFORM | MATION | method | limit/base | current | history 1 | history 2 |
| Sample Number | | | | KC05637683 | KC04825495 | KC04733661 |
| Sample Date | | | | 29 Aug 2022 | 07 Oct 2019 | 13 May 2019 |
| Machine Age | hrs | | | 17181 | 12096 | 8775 |
| Oil Age | hrs | | | 0 | 3321 | 6217 |
| Oil Changed | | | | N/A | Not Changd | Changed |
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |
| WEAR METALS | | method | limit/base | current | history 1 | history 2 |
| Iron | ppm | ASTM D5185m | >50 | 3 | 1 | 2 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | <1 | <1 | <1 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 2 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | <1 | <1 |
| Lead | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | <u>▲</u> 62 | 25 | ▲ 76 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history 1 | history 2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 90 | <1 | 27 | 0 |
| Molybdenum | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 90 | 1 | 55 | 11 |
| Calcium | ppm | ASTM D5185m | 2 | 0 | 2 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 1 | 3 | 5 |
| Zinc | ppm | ASTM D5185m | | 156 | 162 | 200 |
| CONTAMINANTS | 1 | method | limit/base | current | history 1 | history 2 |
| Silicon | ppm | ASTM D5185m | >25 | 0 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | | 0 | 13 | 3 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | <1 |
| Water | % | ASTM D6304 | >0.05 | 0.010 | 0.015 | 0.011 |
| ppm Water | ppm | ASTM D6304 | >500 | 105.7 | 158.4 | 110 |
| FLUID CLEANLIN | IESS | method | limit/base | current | history 1 | history 2 |
| Particles >4µm | | ASTM D7647 | | 49539 | 3884 | 13824 |
| Particles >6µm | | ASTM D7647 | >1300 | 13425 | <u>^</u> 2116 | △ 4185 |
| Particles >14μm | | ASTM D7647 | >80 | <u> </u> | ▲ 360 | ▲ 341 |
| Particles >21µm | | ASTM D7647 | >20 | 476 | <u>121</u> | 1 79 |
| Particles >38µm | | ASTM D7647 | >4 | 48 | <u> </u> | <u>^</u> 6 |
| Particles >71µm | | ASTM D7647 | >3 | 1 | 1 | 1 |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | 23/21/17 | <u>▲</u> 18/16 | △ 19/16 |
| FLUID DEGRADA | TION | method | limit/base | current | history 1 | history 2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.35 | 0.361 | 0.444 |




0.00

OIL ANALYSIS REPORT



| VISUAL | | method | limit/base | current | history 1 | history 2 |
|-------------------------|--------|-----------|------------|---------|-----------|-----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | LIGHT | ▲ MODER | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| FLUID PROPERTIES | | method | limit/base | current | history 1 | history 2 |
| Visc @ 40°C | cSt | ASTM D445 | 46 | 45.3 | 44.3 | 44.2 |
| SAMPLE IMAGES | | method | limit/base | current | history 1 | history 2 |
| Color | | | | | | |
| Bottom | | | | | | |







Certificate L2367

Laboratory Test Package : IND 2

Sample No. Lab Number Unique Number : 10127213

: KC05637683 : 05637683

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 09 Sep 2022 : 14 Sep 2022 Diagnostician : Jonathan Hester

KOCH FOODS 950 INDUSTRIAL BLVD GAINESVILLE, GA USA 30501 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: