


PROBLEM SUMMARY

Sample Rating Trend




Machine Id KAESER ASD40 5428045 (S/N 1125)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION	ATTENTION	NORMAL			
Particles >14μm	ASTM D7647	>80	▲ 83	△ 143	17			
Particles >21μm	ASTM D7647	>20	26	4 8	5			
Oil Cleanliness	ISO 4406 (c)	>17/13	17/14	△ 17/14	15/11			

Customer Id: EDEQUO Sample No.: KCP50309 Lab Number: 05638098 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

22 Sep 2021 Diag: Doug Bogart





Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



29 Jan 2021 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

15 Sep 2020 Diag: Doug Bogart

NORMAL




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER ASD40 5428045 (S/N 1125)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Aug2016	Aug2017 Mar2019	Feb 2020 Sep 2020 S	ep2021	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50309	KCP36353	KCP34109
Sample Date				02 Sep 2022	22 Sep 2021	29 Jan 2021
Machine Age	hrs			30349	25734	21605
Oil Age	hrs			3111	5222	1093
Oil Changed				Changed	Changed	Changed
Sample Status				ATTENTION	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	3	<1	4
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	6	8	9
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	2	2	3
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<1	<1	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	2	1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	145	126	429
Zinc	ppm	ASTM D5185m		57	46	268
Sulfur	ppm	ASTM D5185m		1403	1611	1315
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304		0.001	0.002	0.007
ppm Water	ppm	ASTM D6304	>500	5.9	17.4	70.8
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		2423	2222	936
Particles >6µm		ASTM D7647	>1300	764	880	174
Particles >14μm		ASTM D7647	>80	<u>^</u> 83	<u> </u>	17
Particles >21µm		ASTM D7647	>20	<u>^</u> 26	▲ 48	5
Particles >38µm		ASTM D7647	>4	2	3	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	17/14	▲ 17/14	15/11
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2

0.51




0.00

OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	47.5	46.4	46.2
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom						





Laboratory Sample No. Lab Number

: 05638098 Unique Number : 10127628

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCP50309 Received : 09 Sep 2022

Diagnosed : 13 Sep 2022

Diagnostician : Don Baldridge

EDESIA - INDUSTRIAL REVELATION 550 ROMANO VINYARD WAY QUONSET, RI

USA 02852

Contact:

T:

F:

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)