

PROBLEM SUMMARY

KAESER SK 15T 5760991 (S/N 1734)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	<u> </u>	A 3521			
Particles >14µm	ASTM D7647	>80	🔺 188	A 381			
Particles >21µm	ASTM D7647	>20	<u> </u>	1 29			
Particles >38µm	ASTM D7647	>4	<u> </u>	1 1			
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/15	1 9/16			

Customer Id: ENTMEN Sample No.: KCP33292 Lab Number: 05639092 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 <u>jhester@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS



21 Jan 2022 Diag: Jonathan Hester

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Apr 2021 Diag: Don Baldridge



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

16 Oct 2020 Diag: Angela Borella



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report







OIL ANALYSIS REPORT

Built for a lifetime.

Machine Id KAESER SK 15T 5760991 (S/N 1734) Component

Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	IATION	method	limit/base	current	history 1	history 2
Sample Number				KCP33292	KC95688	KCP28355
Sample Date				07 Sep 2022	21 Jan 2022	23 Apr 2021
Machine Age	hrs			25517	22675	19310
Oil Age	hrs			3000	3000	2500
Oil Changed				Changed	Not Change	Changed
Sample Status				ABNORMAI	ABNORMAL	ABNORMAL
	_					, ibitor in ite
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	12	6	10
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	nnm	ASTM D5185m		0	21	11
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m	30	0	0	0
Manganasa	ppm	ASTM D5185m		0	0	-1
Manganese	ppm	ASTM D5105III	00	0	8	17
Coloium	ppm	ACTM D5105m	20	0	0	0
Decemberue	ppm	ACTM D5105m	2	0	0	6
Zino	ppm	AGTM D5105m		2	2	0
ZITIC Sulfur	ppiii	ACTM DE105m		17204	17715	4
Sullur	ррп	ASTIN DOTOOIII		17304	17715	14901
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		<1	<1	2
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.05	0.026	0.004	0.016
ppm Water	ppm	ASTM D6304	>500	262.8	41.3	164.1
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		7062	12768	
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 3521	
Particles >14µm		ASTM D7647	>80	188	▲ 381	
Particles >21µm		ASTM D7647	>20	<u> </u>	1 29	
Particles >38µm		ASTM D7647	>4	6	1 1	
Particles >71um		ASTM D7647	>3	0	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/15	▲ 19/16	
FLUID DEGRADA		method	limit/base	current	history 1	history 2
Acid Number (AN)	ma KOH/a	ASTM D80/5	0.4	0.37	0.33	0.341
		AG HVI D0040	0.4	0.07	0.00	0.041

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

Contact/Location: SERVICE MANAGER ? - ENTMEN



160k 1404 Ē 120k

<u>8</u> 100 ber of particle 40k 20 0

0ct24/17

Particle Trend 14µm Jan 21/22 Sep7/22 Feb 14/19 InI6/18



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	VLITE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	VLITE	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.4	44.3
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom				()	6	



Contact/Location: SERVICE MANAGER ? - ENTMEN