

PROBLEM SUMMARY

Sample Rating Trend

VIS DEBRIS

Machine Id

KAESER SK 15 7355024 (S/N 1552)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)



COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ATTENTION	ABNORMAL	
Debris	scalar	*Visual	NONE	MODER	NONE	NONE	

Customer Id: PAUBRI Sample No.: KCP48417 Lab Number: 05640358 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

18 Mar 2022 Diag: Jonathan Hester





No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



03 Sep 2021 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



11 Jan 2021 Diag: Jonathan Hester




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



VIS DEBRIS

KAESER SK 15 7355024 (S/N 1552)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2020	Jan 2021	Sep 2021 Mar 2022	Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP48417	KCP45289	KCP37845
Sample Date				24 Aug 2022	18 Mar 2022	03 Sep 2021
Machine Age	hrs			11444	9166	5363
Oil Age	hrs			0	0	3088
Oil Changed				Not Changd	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	5	5	6
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	<1	<1
Barium	ppm	ASTM D5185m	90	5	0	3
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	100	44	76	58
Calcium	ppm	ASTM D5185m	0	<1	10	<1
Phosphorus	ppm	ASTM D5185m	0	1	2	1
Zinc	ppm	ASTM D5185m	0	15	14	4
Sulfur	ppm	ASTM D5185m	23500	18579	16816	16709
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		14	52	20
Potassium	ppm	ASTM D5185m	>20	4	11	6
Water	%	ASTM D6304	>0.05	0.027	0.015	0.024
ppm Water	ppm	ASTM D6304	>500	274.7	156.9	240.8
FLUID CLEANLIN	ESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647			5954	25878
Particles >6µm		ASTM D7647	>1300		<u>▲</u> 1575	<u></u> 15053
Particles >14µm		ASTM D7647	>80		△ 132	<u> </u>
Particles >21µm		ASTM D7647	>20		△ 31	<u></u> 142
Particles >38µm		ASTM D7647	>4		1	3
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		<u> 18/14</u>	<u>△</u> 21/18
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.38	0.36	0.295
	9	. 10 1 111 000-10		0.00		0.200





OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	47.2	47.2	44.4
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom						

GRAPHS Ferrous Alloys













Laboratory Sample No. Lab Number Unique Number : 10129888

: KCP48417 : 05640358

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 13 Sep 2022 Diagnosed

: 15 Sep 2022 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PAUL DOWNS 401 E 4TH ST BRIDGEPORT, PA

USA 19405

Contact: Service Manager

T: F: