


# PROBLEM SUMMARY

## Sample Rating Trend



ISO




Machine Id  
**KAESER 6049836 (S/N 1013)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ABNORMAL	ABNORMAL
Particles >14µm	ASTM D7647 >80	▲ 89	▲ 329	▲ 207
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 20/17/14	▲ 18/16	▲ 20/15

Customer Id: PETBAL  
Sample No.: KCP28716  
Lab Number: 05640372  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

### 15 Jul 2021 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 17 Jul 2020 Diag: Angela Borella

ISO



The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report



Machine Id  
**KAESER 6049836 (S/N 1013)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			<b>KCP28716</b>	KCP41897	KCP10782
Sample Date			<b>12 Sep 2022</b>	15 Jul 2021	17 Jul 2020
Machine Age	hrs		<b>14539</b>	11468	8239
Oil Age	hrs		<b>3142</b>	3229	8239
Oil Changed			<b>Changed</b>	Changed	Changed
Sample Status			<b>ATTENTION</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<b>&lt;1</b>	<1	<1
Chromium	ppm ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m	>3	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	>3	<b>0</b>	0	0
Silver	ppm ASTM D5185m	>2	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185m	>10	<b>&lt;1</b>	0	0
Lead	ppm ASTM D5185m	>10	<b>&lt;1</b>	0	0
Copper	ppm ASTM D5185m	>50	<b>8</b>	12	32
Tin	ppm ASTM D5185m	>10	<b>&lt;1</b>	<1	0
Antimony	ppm ASTM D5185m		<b>---</b>	0	0
Vanadium	ppm ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm ASTM D5185m		<b>&lt;1</b>	<1	0

## ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	<b>0</b>	26	10
Barium	ppm ASTM D5185m	90	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm ASTM D5185m		<b>&lt;1</b>	<1	0
Magnesium	ppm ASTM D5185m	100	<b>30</b>	20	10
Calcium	ppm ASTM D5185m	0	<b>&lt;1</b>	0	0
Phosphorus	ppm ASTM D5185m	0	<b>&lt;1</b>	8	<1
Zinc	ppm ASTM D5185m	0	<b>52</b>	28	31
Sulfur	ppm ASTM D5185m	23500	<b>17761</b>	16986	14203

## CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	<b>&lt;1</b>	2	<1
Sodium	ppm ASTM D5185m		<b>5</b>	8	9
Potassium	ppm ASTM D5185m	>20	<b>2</b>	<1	<1
Water	% ASTM D6304	>0.05	<b>0.015</b>	0.009	0.016
ppm Water	ppm ASTM D6304	>500	<b>157.6</b>	95.4	169.9


## FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		<b>5149</b>	5466	45624
Particles >6µm	ASTM D7647	>1300	<b>1296</b>	▲ 2171	▲ 8535
Particles >14µm	ASTM D7647	>80	▲ <b>89</b>	▲ 329	▲ 207
Particles >21µm	ASTM D7647	>20	<b>18</b>	▲ 86	▲ 35
Particles >38µm	ASTM D7647	>4	<b>1</b>	4	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>20/17/14</b>	▲ 18/16	▲ 20/15

## FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	<b>0.41</b>	0.337	0.360


# OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445 45	47.4	46.5	43.7

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCP28716 **Received** : 13 Sep 2022  
**Lab Number** : 05640372 **Diagnosed** : 15 Sep 2022  
**Unique Number** : 10129902 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**PETER'S SPRINGS & ALIGNMENT**  
 400 ENSOR ST  
 BALTIMORE, MD  
 USA 21202  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: