

# **PROBLEM SUMMARY**


Sample Rating Trend

ISO

# Machine Id KAESER SX 7.5 5274405 (S/N 1123)


Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	NORMAL	ABNORMAL		
Particles >6µm	ASTM D7647	>1300	<b>2603</b>	73	<u></u>		
Particles >14μm	ASTM D7647	>80	<u> </u>	9	<u></u> 580		
Particles >21µm	ASTM D7647	>20	<b>^</b> 59	2	<b>▲</b> 126		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/19/15</b>	13/10	<u>^</u> 20/16		

Customer Id: MCCABS Sample No.: KCP37374 Lab Number: 05640377 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

#### HISTORICAL DIAGNOSIS

#### 02 Aug 2021 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 11 Jan 2021 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 01 Sep 2019 Diag: Doug Bogart

ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# KAESER SX 7.5 5274405 (S/N 1123)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS** Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2016	Jan 2018 Sep 2018	Sep2019 Jan2021 Aug2021	Aug2022	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP37374	KC65019	KCP27221
Sample Date				29 Aug 2022	02 Aug 2021	11 Jan 2021
Machine Age	hrs			11406	9777	9060
Oil Age	hrs			0	0	1500
Oil Changed				Changed	Not Changd	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	12	0	15
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	68	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	4	74	7
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		2	0	11
Zinc	ppm	ASTM D5185m		32	0	46
Sulfur	ppm	ASTM D5185m		15794	16011	16825
CONTAMINANTS	;	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		1	1	5
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.05	0.007	0.034	0.007
ppm Water	ppm	ASTM D6304	>500	76.7	347.1	75.9
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		9202	209	22373
Particles >6µm		ASTM D7647	>1300	<b>^</b> 2603	73	<u></u>
Particles >14μm		ASTM D7647	>80	<u>^</u> 241	9	<u></u> 580
Particles >21µm		ASTM D7647	>20	<b>^</b> 59	2	<u>126</u>
Particles >38μm		ASTM D7647	>4	1	0	<u> 5</u>
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/19/15</b>	13/10	△ 20/16
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
		4.0TH   D.00.45	0.4			


0.21



# **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	43.7	43.6	43.6
SAMPLE IMAGES	3	method	limit/base	current	history 1	history 2
Color						
Bottom						







Laboratory Sample No. Lab Number Unique Number : 10129907

: KCP37374 : 05640377

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 13 Sep 2022 : 15 Sep 2022 Diagnostician : Jonathan Hester

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

123 PLEASANT AVE ABSECON, NJ USA 08201 Contact: CHRISTIE SILVER csilver@mccarthytire.com T:

**MCCARTHY TIRE** 

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: