

PROBLEM SUMMARY

Sample Rating Trend

ISO


8136057 (S/N 7026)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	^ 2040	△ 3414					
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/18/13	<u> </u>					

Customer Id: USYMAROH Sample No.: KCP30901 Lab Number: 05641618 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

03 Mar 2022 Diag: Don Baldridge

ISO




No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



8136057 (S/N 7026)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Mar2022	Sep 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP30901	KCP41104	
Sample Date				06 Sep 2022	03 Mar 2022	
Machine Age	hrs			4551	1481	
Oil Age	hrs			4551	1481	
Oil Changed				Not Changd	Not Changd	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	12	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	<1	87	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	14	93	
Calcium	ppm	ASTM D5185m	0	0	5	
Phosphorus	ppm	ASTM D5185m	0	28	16	
Zinc	ppm	ASTM D5185m	0	8	0	
Sulfur	ppm	ASTM D5185m	23500	9615	17375	
CONTAMINANTS	}	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	3	
Sodium	ppm	ASTM D5185m		4	11	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.006	0.011	
ppm Water	ppm	ASTM D6304	>500	69.3	118.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		10006	15695	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2040	△ 3414	
Particles >14µm		ASTM D7647	>80	76	71	
Particles >21µm		ASTM D7647	>20	16	16	
Particles >38μm		ASTM D7647	>4	0	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/18/13	△ 19/13	
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
A si al Niversala au (ANI)		A OTA A DOO 45	4.0	0.07	0.07	

Acid Number (AN)


mg KOH/g ASTM D8045 1.0


0.37

0.27



OIL ANALYSIS REPORT









Certificate L2367

Laboratory Sample No. Lab Number Unique Number

40

: KCP30901 : 05641618 : 10131148

Viscosity @ 40°C

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 14 Sep 2022 Diagnosed

: 15 Sep 2022 Diagnostician : Angela Borella Test Package : IND 2 (Additional Tests: KF, PrtCount)

Contact/Location: Service Manager - USYMAROH

Acid Number

(B) 1.20 0.96 € 0.72

은 0.48

0.24 0.00

USA 43302

Contact: Service Manager

1177 KELLOGG PKWY

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **US YACHIYO**

MARION, OH

T: