


PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
KAESER 6427839

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>1300	▲ 32016	▲ 2439	▲ 2451
Particles >14µm	ASTM D7647	>80	▲ 997	▲ 224	▲ 180
Particles >21µm	ASTM D7647	>20	▲ 62	▲ 56	▲ 42
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 23/22/17	▲ 18/15	▲ 18/15

Customer Id: KROAUR
Sample No.: KCP41313
Lab Number: 05644888
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

10 Feb 2022 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Aug 2021 Diag: Don Baldrige

ISO



The oil change at the time of sampling has been noted. We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Sep 2020 Diag: Angela Borella

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER 6427839
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KCP41313	KCP48662	KCP37833
Sample Date			01 Sep 2022	10 Feb 2022	23 Aug 2021
Machine Age	hrs		16600	14266	12555
Oil Age	hrs		2334	2000	3164
Oil Changed			Changed	Changed	Changed
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<1	0	0
Chromium	ppm ASTM D5185m	>10	0	0	0
Nickel	ppm ASTM D5185m	>3	0	0	0
Titanium	ppm ASTM D5185m	>3	0	0	0
Silver	ppm ASTM D5185m	>2	<1	<1	<1
Aluminum	ppm ASTM D5185m	>10	<1	<1	0
Lead	ppm ASTM D5185m	>10	0	<1	0
Copper	ppm ASTM D5185m	>50	2	2	7
Tin	ppm ASTM D5185m	>10	<1	0	0
Antimony	ppm ASTM D5185m		---	0	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	0	0	15
Barium	ppm ASTM D5185m	90	17	36	0
Molybdenum	ppm ASTM D5185m	0	0	0	0
Manganese	ppm ASTM D5185m		0	0	0
Magnesium	ppm ASTM D5185m	100	51	81	4
Calcium	ppm ASTM D5185m	0	<1	<1	0
Phosphorus	ppm ASTM D5185m	0	2	4	0
Zinc	ppm ASTM D5185m	0	5	2	<1
Sulfur	ppm ASTM D5185m	23500	17902	17721	18022

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	0	<1	0
Sodium	ppm ASTM D5185m		19	19	2
Potassium	ppm ASTM D5185m	>20	0	3	0
Water	% ASTM D6304	>0.05	0.018	0.012	0.006
ppm Water	ppm ASTM D6304	>500	185.1	125.2	65.8


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		77708	7105	9616
Particles >6µm	ASTM D7647	>1300	▲ 32016	▲ 2439	▲ 2451
Particles >14µm	ASTM D7647	>80	▲ 997	▲ 224	▲ 180
Particles >21µm	ASTM D7647	>20	▲ 62	▲ 56	▲ 42
Particles >38µm	ASTM D7647	>4	1	1	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 23/22/17	▲ 18/15	▲ 18/15

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	0.32	0.38	0.391


OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	46.7	47.3

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP41313 **Received** : 19 Sep 2022
Lab Number : 05644888 **Diagnosed** : 20 Sep 2022
Unique Number : 10139427 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

KROGER
 1933 TOWER RD
 AURORA, CO
 USA 80011
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: