


PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
KAESER ASD 40 4672450 (S/N 1022)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | ABNORMAL | ATTENTION | ABNORMAL |
|-----------------|--------------|--------|----------|-----------|----------|
| Particles >6µm | ASTM D7647 | >1300 | ▲ 8504 | ▲ 1537 | ▲ 8206 |
| Particles >14µm | ASTM D7647 | >80 | ▲ 764 | ▲ 144 | ▲ 1658 |
| Particles >21µm | ASTM D7647 | >20 | ▲ 194 | ▲ 48 | ▲ 540 |
| Oil Cleanliness | ISO 4406 (c) | >17/13 | ▲ 20/17 | ▲ 18/14 | ▲ 20/18 |

Customer Id: LRPDEN
Sample No.: KCP40463
Lab Number: 05644894
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

29 Mar 2022 Diag: Doug Bogart

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Sep 2021 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Dec 2020 Diag: Angela Borella

ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER ASD 40 4672450 (S/N 1022)

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history 1 | history 2 |
|---------------|--------|------------|--------------------|-------------|-------------|
| Sample Number | | | KCP40463 | KCP45301 | KCP42784 |
| Sample Date | | | 08 Sep 2022 | 29 Mar 2022 | 09 Sep 2021 |
| Machine Age | hrs | | 26263 | 25047 | 23581 |
| Oil Age | hrs | | 316 | 0 | 2005 |
| Oil Changed | | | Not Changed | Changed | Changed |
| Sample Status | | | ABNORMAL | ATTENTION | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history 1 | history 2 |
|----------|--------|-----------------|---------|-----------|-----------|
| Iron | ppm | ASTM D5185m >50 | <1 | <1 | 0 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | <1 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m >10 | 1 | <1 | <1 |
| Lead | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >50 | 3 | 2 | 4 |
| Tin | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history 1 | history 2 |
|------------|--------|-------------------|---------|-----------|-----------|
| Boron | ppm | ASTM D5185m 0 | 0 | <1 | 1 |
| Barium | ppm | ASTM D5185m 90 | 39 | 55 | 27 |
| Molybdenum | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 100 | 56 | 88 | 41 |
| Calcium | ppm | ASTM D5185m 0 | <1 | 2 | <1 |
| Phosphorus | ppm | ASTM D5185m 0 | 3 | 4 | <1 |
| Zinc | ppm | ASTM D5185m 0 | 6 | 1 | 8 |
| Sulfur | ppm | ASTM D5185m 23500 | 17777 | 17312 | 17327 |

CONTAMINANTS

| | method | limit/base | current | history 1 | history 2 |
|-----------|--------|------------------|---------|-----------|-----------|
| Silicon | ppm | ASTM D5185m >25 | <1 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | 20 | 19 | 15 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 2 | 0 |
| Water | % | ASTM D6304 >0.05 | 0.015 | 0.008 | 0.016 |
| ppm Water | ppm | ASTM D6304 >500 | 157.0 | 80.7 | 164.4 |


FLUID CLEANLINESS

| | method | limit/base | current | history 1 | history 2 |
|-----------------|--------------|------------|---------|-----------|-----------|
| Particles >4µm | ASTM D7647 | | 30931 | 5921 | 19157 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 8504 | ▲ 1537 | ▲ 8206 |
| Particles >14µm | ASTM D7647 | >80 | ▲ 764 | ▲ 144 | ▲ 1658 |
| Particles >21µm | ASTM D7647 | >20 | ▲ 194 | ▲ 48 | ▲ 540 |
| Particles >38µm | ASTM D7647 | >4 | 3 | 4 | ▲ 19 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >17/13 | ▲ 20/17 | ▲ 18/14 | ▲ 20/18 |

FLUID DEGRADATION

| | method | limit/base | current | history 1 | history 2 |
|------------------|----------|----------------|---------|-----------|-----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 1.0 | 0.39 | 0.43 | 0.369 |


OIL ANALYSIS REPORT





| VISUAL | method | limit/base | current | history 1 | history 2 | |
|------------------|--------|------------|---------|--------------|-----------|-------|
| White Metal | scalar | *Visual | NONE | LIGHT | NONE | LIGHT |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history 1 | history 2 | |
|------------------|--------|------------|---------|-------------|-----------|------|
| Visc @ 40°C | cSt | ASTM D445 | 45 | 46.4 | 47.4 | 47.4 |

| SAMPLE IMAGES | method | limit/base | current | history 1 | history 2 |
|---------------|--------|------------|---------|-----------|-----------|
|---------------|--------|------------|---------|-----------|-----------|



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP40463 **Received** : 19 Sep 2022
Lab Number : 05644894 **Diagnosed** : 20 Sep 2022
Unique Number : 10139433 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

L & R PALLET
 3855 LIMA ST
 DENVER, CO
 USA 80239
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: