

PROBLEM SUMMARY

Sample Rating Trend

Rating Trend
ISO


KAESER 7181271

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL					
Particles >6µm	ASTM D7647	>1300	2993	567					
Particles >14µm	ASTM D7647	>80	152	8					
Particles >21µm	ASTM D7647	>20	45	0					
Oil Cleanliness	ISO 4406 (c)	>/17/13	21/19/14	16/10					

Customer Id: UNIKAN Sample No.: KCP37305 Lab Number: 05645556 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

Action Status Date Done By Description Change Fluid --- ? Oil and filter change at the time of sampling has been noted. Change Filter --- ? Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

10 Aug 2021 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER 7181271

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Aug2021	Aug2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP37305	KCP41545	
Sample Date				30 Aug 2022	10 Aug 2021	
Machine Age	hrs			6941	4494	
Oil Age	hrs			3000	4000	
Oil Changed				Changed	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	28	45	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	<1	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	17	13	
Calcium	ppm	ASTM D5185m	2	0	1	
Phosphorus	ppm	ASTM D5185m		4	8	
Zinc	ppm	ASTM D5185m		92	49	
Sulfur	ppm	ASTM D5185m		17469	15457	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		3	1	
Potassium	ppm	ASTM D5185m	>20	0	6	
Water	%	ASTM D6304	>0.05	0.016	0.009	
ppm Water	ppm	ASTM D6304	>500	166.3	94.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		14302	1337	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2993	567	
Particles >14μm		ASTM D7647	>80	<u> </u>	8	
Particles >21µm		ASTM D7647	>20	45	0	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/14	16/10	
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.41	0.303	



OIL ANALYSIS REPORT









Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCP37305 : 05645556 : 10140095

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 22 Sep 2022 Diagnostician : Jonathan Hester

: 19 Sep 2022

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

UNIFIRST CORP

no image

2601 E TRUMAN RD KANSAS CITY, MO

USA 64127

Contact: Service Manager