


PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
4379049 (S/N 1114)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	ABNORMAL	---
Particles >6µm	ASTM D7647	>1300	▲ 1410	▲ 32271	---
Particles >14µm	ASTM D7647	>80	▲ 84	▲ 2668	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 19/18/14	▲ 22/19	---

Customer Id: ATLNEWNJJC
Sample No.: KC102911
Lab Number: 05646066
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

29 Jun 2020 Diag: Don Baldrige

ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
4379049 (S/N 1114)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KC102911	KC83227	---
Sample Date			15 Sep 2022	29 Jun 2020	---
Machine Age	hrs		27814	22615	---
Oil Age	hrs		2572	3032	---
Oil Changed			Changed	Changed	---
Sample Status			ATTENTION	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m >50	<1	1	---
Chromium	ppm	ASTM D5185m >10	0	0	---
Nickel	ppm	ASTM D5185m >3	0	1	---
Titanium	ppm	ASTM D5185m >3	0	0	---
Silver	ppm	ASTM D5185m >2	0	0	---
Aluminum	ppm	ASTM D5185m >10	<1	<1	---
Lead	ppm	ASTM D5185m >10	0	2	---
Copper	ppm	ASTM D5185m >50	8	14	---
Tin	ppm	ASTM D5185m >10	0	0	---
Antimony	ppm	ASTM D5185m	---	0	---
Vanadium	ppm	ASTM D5185m	0	<1	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m 0	0	0	---
Barium	ppm	ASTM D5185m 90	8	<1	---
Molybdenum	ppm	ASTM D5185m 0	0	0	---
Manganese	ppm	ASTM D5185m	<1	<1	---
Magnesium	ppm	ASTM D5185m 100	41	24	---
Calcium	ppm	ASTM D5185m 0	<1	<1	---
Phosphorus	ppm	ASTM D5185m 0	<1	2	---
Zinc	ppm	ASTM D5185m 0	23	35	---

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m >25	1	2	---
Sodium	ppm	ASTM D5185m	13	7	---
Potassium	ppm	ASTM D5185m >20	0	3	---
Water	%	ASTM D6304 >0.05	0.017	0.020	---
ppm Water	ppm	ASTM D6304 >500	177.2	200.3	---


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		3873	62542	---
Particles >6µm	ASTM D7647	>1300	▲ 1410	▲ 32271	---
Particles >14µm	ASTM D7647	>80	▲ 84	▲ 2668	---
Particles >21µm	ASTM D7647	>20	9	▲ 474	---
Particles >38µm	ASTM D7647	>4	0	▲ 28	---
Particles >71µm	ASTM D7647	>3	0	▲ 15	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 19/18/14	▲ 22/19	---

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.37	0.393	---


OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	49.1	50.0

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC102911 **Received** : 20 Sep 2022
Lab Number : 05646066 **Diagnosed** : 21 Sep 2022
Unique Number : 10140605 **Diagnostician** : Doug Bogart
Test Package : IND 2

ATLAS WOODWORKING
 212 WRIGHT ST
 NEWARK, NJ
 USA 07114
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: