


PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id
7900472 (S/N 1185)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ATTENTION
Water	%	ASTM D6304	>0.05	▲ 0.067	▲ 0.534	0.025
ppm Water	ppm	ASTM D6304	>500	▲ 672.0	▲ 5340	259.2

Customer Id: INTROCNJ
Sample No.: KC95974
Lab Number: 05647251
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

24 Feb 2022 Diag: Angela Borella

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a trace of moisture present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



25 Aug 2021 Diag: Don Baldrige

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



Machine Id
7900472 (S/N 1185)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

▲ Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KC95974	KC94691	KC86463
Sample Date			14 Sep 2022	24 Feb 2022	25 Aug 2021
Machine Age	hrs		12240	7080	3039
Oil Age	hrs		3000	3000	3039
Oil Changed			Changed	Changed	Changed
Sample Status			ABNORMAL	ABNORMAL	ATTENTION

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	0	<1	<1
Chromium	ppm ASTM D5185m	>10	0	0	0
Nickel	ppm ASTM D5185m	>3	0	0	0
Titanium	ppm ASTM D5185m	>3	0	0	0
Silver	ppm ASTM D5185m	>2	0	<1	0
Aluminum	ppm ASTM D5185m	>10	<1	<1	0
Lead	ppm ASTM D5185m	>10	0	0	0
Copper	ppm ASTM D5185m	>50	4	3	4
Tin	ppm ASTM D5185m	>10	0	0	0
Antimony	ppm ASTM D5185m		---	0	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	0	1	13
Barium	ppm ASTM D5185m	90	19	1	0
Molybdenum	ppm ASTM D5185m	0	0	0	0
Manganese	ppm ASTM D5185m		0	<1	<1
Magnesium	ppm ASTM D5185m	100	54	56	44
Calcium	ppm ASTM D5185m	0	<1	5	1
Phosphorus	ppm ASTM D5185m	0	2	11	3
Zinc	ppm ASTM D5185m	0	3	6	0

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	<1	1	<1
Sodium	ppm ASTM D5185m		12	9	10
Potassium	ppm ASTM D5185m	>20	0	2	4
Water	% ASTM D6304	>0.05	▲ 0.067	▲ 0.534	0.025
ppm Water	ppm ASTM D6304	>500	▲ 672.0	▲ 5340	259.2


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		912	---	5095
Particles >6µm	ASTM D7647	>1300	190	---	▲ 1919
Particles >14µm	ASTM D7647	>80	1	---	▲ 103
Particles >21µm	ASTM D7647	>20	0	---	▲ 32
Particles >38µm	ASTM D7647	>4	0	---	3
Particles >71µm	ASTM D7647	>3	0	---	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	17/15/7	---	▲ 18/14

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	0.34	0.36	0.282


OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	43.5	46.0

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC95974 **Received** : 21 Sep 2022
Lab Number : 05647251 **Diagnosed** : 22 Sep 2022
Unique Number : 10141790 **Diagnostician** : Doug Bogart
Test Package : IND 2

INTEGRITY PRECISION PRODUCTS
 24 LINK DR, UNIT C
 ROCKLEIGH, NJ
 USA 07647
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: