

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id


KAESER SM 11 1858983 (S/N 1437)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ABNORMAL	NORMAL	ABNORMAL			
Particles >6µm	ASTM D7647 >1300	4159	521	<u>^</u> 2068			
Particles >14μm	ASTM D7647 >80	A 846	67	△ 325			
Particles >21µm	ASTM D7647 >20	^ 265	22	<u></u> 102			
Particles >38μm	ASTM D7647 >4	4 31	4	<u> </u>			
Particles >71μm	ASTM D7647 >3	<u>^</u> 2	0	<u></u> 4			
Oil Cleanliness	ISO 4406 (c) >/17/	13 <u>20/19/17</u>	16/13	▲ 18/16			

Customer Id: LAZSUMIL Sample No.: KCP46309 Lab Number: 05647878 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

12 Nov 2019 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 Jan 2018 Diag: Doug Bogart

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER SM 11 1858983 (S/N 1437)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Jan 2018		Nov2019 Sep20	22		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2	
Sample Number				KCP46309	KCP23659	KCP03656	
Sample Date				14 Sep 2022	12 Nov 2019	10 Jan 2018	
Machine Age	hrs			27723	25281	22192	
Oil Age	hrs			2500	4000	0	
Oil Changed				Changed	Changed	Changed	
Sample Status				ABNORMAL	NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2	
Iron	ppm	ASTM D5185m	>50	<1	<1	1	
Chromium	ppm	ASTM D5185m	>10	0	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	0	
Lead	ppm	ASTM D5185m	>10	0	<1	<1	
Copper	ppm	ASTM D5185m	>50	7	9	19	
Tin	ppm	ASTM D5185m	>10	<1	0	0	
Antimony	ppm	ASTM D5185m			0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m	0	0	<1	0	
Barium	ppm	ASTM D5185m	90	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	0	
Manganese	ppm	ASTM D5185m		<1	1	<1	
Magnesium	ppm	ASTM D5185m	100	18	22	4	
Calcium	ppm	ASTM D5185m	0	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	<1	2	51	
Zinc	ppm	ASTM D5185m	0	11	11	10	
Sulfur	ppm	ASTM D5185m	23500	22357	4905	19306	
CONTAMINANTS	}	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185m	>25	<1	1	3	
Sodium	ppm	ASTM D5185m		2	6	1	
Potassium	ppm	ASTM D5185m	>20	<1	2	2	
Water	%	ASTM D6304		0.016	0.012	0.005	
ppm Water	ppm	ASTM D6304	>500	160.0	127.9	50	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2	
Particles >4μm		ASTM D7647		9072	1569	5702	
Particles >6µm		ASTM D7647	>1300	<u>4159</u>	521	<u>▲</u> 2068	
Particles >14μm		ASTM D7647	>80	<u> </u>	67	▲ 325	
Particles >21µm		ASTM D7647	>20	<u>^</u> 265	22	▲ 102	
Particles >38μm		ASTM D7647	>4	△ 31	4	<u> </u>	
Particles >71μm		ASTM D7647	>3	<u>^</u> 2	0	<u>4</u>	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/17	16/13	<u>▲</u> 18/16	
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2	
A : I A : (65.1)	1/011/	1071100015	4.0		0.0=0	0.44=	



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	47.6	47.9	47.5
SAMPLE IMAGES		method	limit/base	current	history 1	history 2
Color						
Bottom						







Laboratory Sample No. Lab Number Unique Number : 10142417

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCP46309 : 05647878

Received Diagnosed

Diagnostician : Jonathan Hester

: 21 Sep 2022 : 22 Sep 2022

SUMNER, IL USA 62466 Contact: Service Manager

LAZY 8 BODY SHOP

8831 EAST IL 250

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: