


# **PROBLEM SUMMARY**

Machine Id **6254733 (S/N 1831)** 


Component

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)



## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST	RESULTS				
Sample Status			ABNORMAL	ABNORMAL	
Particles >6μm	ASTM D7647	>1300	<b>2912</b>	<b>▲</b> 8359	
Particles >14μm	ASTM D7647	>80	<b>220</b>	<u></u> 712	
Particles >21µm	ASTM D7647	>20	<b>44</b>	<u>151</u>	
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>21/19/15</b>	<u>^</u> 20/17	

**Customer Id: RELUNI** Sample No.: KCP37341 Lab Number: 05648918 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# Action Status Date Done By Description Change Fluid --- ? Oil and filter change at the time of sampling has been noted. Change Filter --- ? Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

## 11 Aug 2021 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

Sample Rating Trend ISO

6254733 (S/N 1831)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

## **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Aug2021	Sep 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP37341	KCP21469	
Sample Date				21 Sep 2022	11 Aug 2021	
Machine Age	hrs			20552	15989	
Oil Age	hrs			5000	9521	
Oil Changed				Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	10	11	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m	210		0	
Vanadium		ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
Caumum	ppm	ASTIVI DOTOSIII		U	U	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	16	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	0	0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	12	2	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	21609	16239	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	6	13	
Sodium	ppm	ASTM D5185m		0	1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.013	0.011	
ppm Water	ppm	ASTM D6304	>500	133.7	119.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm						
i artiolog > ipini		ASTM D7647		10511	30331	
Particles >6μm		ASTM D7647 ASTM D7647	>1300	10511 <u>2912</u>	30331 <b>A</b> 8359	
·			>1300 >80			
Particles >6μm		ASTM D7647		<u>^</u> 2912	<u>▲</u> 8359	
Particles >6μm Particles >14μm		ASTM D7647 ASTM D7647	>80	△ 2912 △ 220	▲ 8359 ▲ 712	
Particles >6µm Particles >14µm Particles >21µm		ASTM D7647 ASTM D7647 ASTM D7647	>80 >20 >4	△ 2912 △ 220 △ 44	▲ 8359 ▲ 712 ▲ 151	
Particles >6μm Particles >14μm Particles >21μm Particles >38μm		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>80 >20 >4	▲ 2912 ▲ 220 ▲ 44 2	▲ 8359 ▲ 712 ▲ 151 ▲ 11	
Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm	TION	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>80 >20 >4 >3	△ 2912 △ 220 △ 44 2 0	▲ 8359 ▲ 712 ▲ 151 ▲ 11 0	

0.52



## **OIL ANALYSIS REPORT**





GRAPHS	A Portido Ct	
Ferrous Alloys	Particle Count	· · · · · · · · · · · · · · · · · · ·
iron	102.000	
• • • • • • • • • • • • • • • • • • •	122,880	
	30,720	
	7,680	
Aug11/21.	Sep 21/22 ( (ber 1 m))	
	des se	
Non-ferrous Metals	Sep21222 Sep21221 [III] 1,920 - 480 - 120	
copper	in 120 -	
announce till	30+	
	<sup>8</sup> <b>Borese</b> mal	
Aug11/21	2-	
Augl	Sep21/22	
Viscosity @ 40°C	4μ 6μ 14μ Acid Number	21μ 38μ 71,
Severe	⊋ 1.20 <b>Abso</b> rmal	
Abnormal	9 0.96 + <del>9</del>	
Base	1.20   Bheemal   Bheemal	
Abnormal Severe	0.24	
<del>-</del>		
Aug11/21	Sep21/22	



Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: KCP37341 : 05648918 : 10143457

**Bottom** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Sep 2022

Diagnosed : 26 Sep 2022 Diagnostician : Angela Borella

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

USA 94587 Contact: Service Manager

**RELIANCE STEEL** 

UNION CITY, CA

33201 WESTERN AVE

T: F:

Report Id: RELUNI [WUSCAR] 05648918 (Generated: 09/26/2022 09:27:39)

Contact/Location: Service Manager - RELUNI

no image