


PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
4144746 (S/N 1064)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	NORMAL
Particles >6µm	ASTM D7647	>1300	▲ 9365	▲ 3600	868
Particles >14µm	ASTM D7647	>80	▲ 546	▲ 245	43
Particles >21µm	ASTM D7647	>20	▲ 64	▲ 76	9
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 22/20/16	▲ 19/15	17/13

Customer Id: PRIVES
Sample No.: KCP28640
Lab Number: 05648934
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Feb 2022 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Aug 2021 Diag: Angela Borella

NORMAL



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Jan 2021 Diag: Don Baldrige

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
4144746 (S/N 1064)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			KCP28640	KCP38154	KCP37567
Sample Date			19 Sep 2022	02 Feb 2022	03 Aug 2021
Machine Age	hrs		81631	76332	72002
Oil Age	hrs		5299	4330	4604
Oil Changed			Not Changed	Changed	Changed
Sample Status			ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<1	<1	0
Chromium	ppm ASTM D5185m	>10	<1	0	0
Nickel	ppm ASTM D5185m	>3	<1	0	0
Titanium	ppm ASTM D5185m	>3	<1	0	0
Silver	ppm ASTM D5185m	>2	0	0	0
Aluminum	ppm ASTM D5185m	>10	0	<1	0
Lead	ppm ASTM D5185m	>10	1	0	0
Copper	ppm ASTM D5185m	>50	2	<1	1
Tin	ppm ASTM D5185m	>10	<1	0	0
Antimony	ppm ASTM D5185m		---	0	0
Vanadium	ppm ASTM D5185m		<1	0	0
Cadmium	ppm ASTM D5185m		<1	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	<1	23	0
Barium	ppm ASTM D5185m	90	18	12	10
Molybdenum	ppm ASTM D5185m	0	<1	0	0
Manganese	ppm ASTM D5185m		<1	0	0
Magnesium	ppm ASTM D5185m	100	55	80	65
Calcium	ppm ASTM D5185m	0	7	2	0
Phosphorus	ppm ASTM D5185m	0	18	3	5
Zinc	ppm ASTM D5185m	0	13	0	0
Sulfur	ppm ASTM D5185m	23500	12606	18582	17410

CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>25	2	<1	0
Sodium	ppm ASTM D5185m		14	17	17
Potassium	ppm ASTM D5185m	>20	10	0	2
Water	% ASTM D6304	>0.05	0.025	0.014	0.037
ppm Water	ppm ASTM D6304	>500	257.4	142.3	370.9


FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		30711	12136	2974
Particles >6µm	ASTM D7647	>1300	▲ 9365	▲ 3600	868
Particles >14µm	ASTM D7647	>80	▲ 546	▲ 245	43
Particles >21µm	ASTM D7647	>20	▲ 64	▲ 76	9
Particles >38µm	ASTM D7647	>4	1	▲ 6	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 22/20/16	▲ 19/15	17/13

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	1.0	0.40	0.37	0.369


OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	45	46.6	47.4

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP28640 **Received** : 22 Sep 2022
Lab Number : 05648934 **Diagnosed** : 26 Sep 2022
Unique Number : 10143473 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

PRINT PROMOTIONS GROUP LLC
 2100 COLUMBIANA RD
 VESTAVIA HILLS, AL
 USA 35216
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: