

PROBLEM SUMMARY

Sample Rating Trend

ISO


2524451 (S/N 1043)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	ABNORMAL					
Particles >14µm	ASTM D7647	>80	<u> </u>	72					
Particles >21µm	ASTM D7647	>20	22	24					
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/17/14	16/13					

Customer Id: LEVBUF Sample No.: KCP50695 Lab Number: 05648955 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

HISTORICAL DIAGNOSIS

07 Jul 2021 Diag: Doug Bogart

WATER




Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. Excessive free water present. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT



2524451 (S/N 1043)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2021	Aug2022		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number				KCP50695	KCP42250	
Sample Date				02 Aug 2022	07 Jul 2021	
Machine Age	hrs			23639	22173	
Oil Age	hrs			1500	5150	
Oil Changed				Changed	Changed	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	20	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
	le le · · ·			-		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	24	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	47	26	
Calcium	ppm	ASTM D5185m	2	2	<1	
Phosphorus	ppm	ASTM D5185m		11	9	
Zinc	ppm	ASTM D5185m		27	19	
Sulfur	ppm	ASTM D5185m		20970	16161	
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		10	6	
Potassium	ppm	ASTM D5185m	>20	6	7	
Water	%	ASTM D6304	>0.05	0.042	△ 0.465	
ppm Water	ppm	ASTM D6304	>500	425.1	<u>▲</u> 4647	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		5094	776	
Particles >6µm		ASTM D7647	>1300	1084	423	
Particles >14µm		ASTM D7647	>80	<u> </u>	72	
Particles >21µm		ASTM D7647	>20	<u>^</u> 22	24	
Particles >38µm		ASTM D7647	>4	2	4	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>20/17/14</u>	16/13	
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2


0.459

0.32



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCP50695 : 05648955 : 10143494

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 26 Sep 2022 Diagnosed Diagnostician : Jonathan Hester

: 22 Sep 2022

Test Package : IND 2 (Additional Tests: KF, PrtCount)

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: Service Manager

LEVOLOR INC

BUFORD, GA

USA 30518

T: F:

1750 SATELITE BLVD

history 2

history 2

history 2

no image

no image